



Report of Materials and Equipment
Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 67 -02-E Vol. VII

Manufacturer: Notifier, 12 Clintonville Road, Northford, CT 06472-1001.
Trade Name(s): Gamewell Company.
Product: Fire Alarm Pull Boxes.
Pertinent Code Section(s): 27-968 through 27-977, RS 17-5, ANSI/NFPA No. 72.
Test(s): RS 17-5 ANSI/NFPA No. 72; UL Standard 38.
Laboratory: Underwriters Laboratories Inc.
Test Report(s): UL multiple listing files: S281, Issued April 5, 2004, revised July 15, 2004.

Description: Fire Protection Equipment.

Table with 3 columns: Product Description, Notifier, Gamewell. Rows include Dual action, addressable, pull station and Single action, addressable, Dull station.

Terms and Conditions: That the above units be accepted on condition that all uses, configurations, arrangements, and functions, applications and installations shall comply with the provisions of the New York City Building Codes, specifically Subchapter 17 and with Reference Standards RS 17-3 through RS 17-5, NFPA 72, the UL Listing, UL 38 Standard, the manufacturer's instructions, the Fire Department Rules and the New York City Electrical Code.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the materials shipped or delivered are equivalent to that tested and accepted for use, as provided in Section 27-131 of the Building Code.

Final Acceptance September 2005
Examined by Donald [Signature]