



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 68-07-E

Manufacturer: Motivair Corporation, 25 John Glenn Drive, Amherst, N.Y. 14228

Trade Name(s): Motivair

Product: Packaged water chillers

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11A (UL 1995)

Laboratory: Intertek, ETL Semko

Test Report(s): 3085645-002, dated December 20, 2005 and revised March 7, 2006.

Description: Packaged air-cooled liquid chillers, MPC series. Units are equipped with compressors, condenser coils, brazed-plate evaporators, fan motors and controls. Units, with model numbers and cooling capacities, are listed below:

Model No.	Mfr's. Specified Nominal Cooling Capacities (Tons)
MPC-005	0.5
MPC-0010	1
MPC-0150	1.5
MPC-0200	2
MPC-0300	3
MPC-0500	5
MPC-0800	7
MPC-1000	9
MPC-1200	10.5
MPC-2200	15
MPC-3000	20
MPC-3500	25
MPC-4000	30
MPC-5000	40
MPC-6000	45
MPC-7200	50

Terms and Conditions: The above-described units are accepted under the following conditions:

1. Units may use Refrigerants R-22, R-134a or R-407C.
2. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
3. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
4. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
5. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance 10/15/07

Examined By Shyam. Oran