

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 72-04-E

Report of Material and Equipment Acceptance Division

Manufacturer– The Thelin Co., Inc., 12400 Loma Rica, Dr. #5, Grass Valley, CA 95945.

Trade Name – Thelin.

Product – Gas fired vented decorative fireplace appliance.

Pertinent Code Section(s) – 27-800, RS 14-2 (ANSI Z223).

Prescribed Test(s) - RS 14-6 (ANSI Z21.88-2002).

Laboratory – CSA International.

Test Report(s) – No. 201096, dated December 29, 2003.

Description – Gas fired decorative fireplace appliance designed to provide supplemental heating and to enhance the aesthetics of a room. Units are equipped with electric ignition.

Model No.	Electrical Rating	Maximum Input Rating	Minimum Input Rating
For use with natural gas direct vent, freestanding, fireplace heaters:			
PARLOUR 3000DV Gas	Op. Fans, 120 V, 60 Hz, less than 12 A	31,000	18,600
GNOME DV Gas	Op. Fans, 120 V, 60 Hz, less than 12 A	22,000	13,200
ECHO Stove	No fans, Millivolt System Only	27,000	15,000

Recommendation - That the above described gas fired vented appliance be accepted for decorative heating operation on natural gas only, for indoor installation only with combustible air and required ventilation air provided. Venting of the above equipment is subject to Section 27-879 of the Building Code. Approval of all electric equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 3/15/04

Examined By Supriya J. Javed