



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 72- 07-E

Manufacturer: Rheem Manufacturing Co., P.O. Box 17010, Fort Smith, AR 72917-7010

Trade Name(s): Rheem, Ruud, Weatherking

Product: Packaged air conditioner units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS13-11B (ANSI B9.1), RS13-11 (UL 1995, UL 465)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): SA7930, dated December 12, 1994, revised January 8, 1997

Description: Single-packaged cooling units designed for outdoor installation and for use with ductwork connected to conditioned space. Cooling section employs refrigerant R-22. Cooling section is comprised of hermetically-sealed compressor, air-cooled condenser, evaporator coil with fan motor, blower motor, expansion valve and safety controls. Units, with model number and cooling capacities, are listed below:

Model No.	Mfr.'s Specified Nominal Cooling Capacity (Tons)
RSNA-C060*	5.0

* Denotes additional characters in model number.

Terms and Conditions: The above-described packaged air conditioner units are accepted with the following conditions:

1. Units shall use only Refrigerant R-22.
2. Units shall be installed outdoors only.
3. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, subdivision 4 of the New York City Building Code, as to maximum sound levels permitted for exterior mechanical equipment.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Department's Electrical Advisory Board before installation.
5. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

NOTE: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance April 24, 2007

Examined By Simon Derkshon