



NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 73-92-E Vol. XXXI

Manufacturer: Air Products and Controls Inc.

Trade Name(s): Air Products and Controls Inc.

Product: Smoke-Automatic Fire Detector Accessories: MSR-100R/W, MSR-100R/R, MSR-100R/S, MSR-100RS/W/C, MSR-100RS/W/O, MSR-100RS/R/C, MSR-100RS/R/O, MSR-RS/S/C, MSR-100RS/S/O.

Pertinent Code Section(s): Reference Standard 17.

Test(s): UL 268, UL 268A.

Laboratory: Underwriters Laboratories Inc

Test Report(s): File S7425, Project 00NK02701, June 27, 2000, revised April 22, 2005. UL Report dated April 12, 2005.

Description – The MSR Series Smoke-Automatic Fire Detector Accessories are to be only used with MEA approved RW, SM-501 Series and SL-2000 Series duct detectors to provide audible and visual indication as well as remote test/reset functions, which re-intended for energization from a separate signaling circuit. The notification appliances are supplemental and are not intended as the primary evacuation signal appliance.

Model No.	Description
MSR-100R/W	Remote Indicator/Control Assembly with White Plastic Single Gang Face Plate
MSR-100R/R	Remote Indicator/Control Assembly with Red Plastic Single Gang Face Plate
MSR-100R/S	Remote Indicator/Control Assembly with Stainless Steel Single Gang Face Plate
MSR-100RS/W/C	Remote Indicator/Control Assembly with Strobe Assembly (Clear Lens) and White Plastic Double Gang Face Plate
MSR-100RS/W/O	Remote Indicator/Control Assembly with Strobe Assembly (Opaque Lens) and White Plastic Double Gang Face Plate
MSR-100RS/R/C	Remote Indicator/Control Assembly with Strobe Assembly (Clear Lens) and Red Plastic Double Gang Face Plate
MSR-100RS/R/O	Remote Indicator/Control Assembly with Strobe Assembly (Opaque Lens) and Red Plastic Double Gang Face Plate

MSR-100RS/S/C	Remote Indicator/Control Assembly with Strobe Assembly (Clear Lens) and Stainless Steel Plastic Double Gang Face Plate
MSR-100RS/S/O	Remote Indicator/Control Assembly with Strobe Assembly (Opaque Lens) and Stainless Steel Plastic Double Gang Face Plate

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections letter dated August 30, 2005, F.P. Index No. 0507040.

Terms and Conditions: That the above units are accepted on condition that:

1. The above referenced notification devices shall be used only in private mode.
2. All uses, configurations, arrangements and functions, application and installations shall comply with all applicable provisions of New York City Building Code, specifically Subchapter 17 and Reference Standards 17-3. Further, the installation and use shall be in accordance with manufacturer's recommendations, NFPA 72 and UL Standard.

All shipments and deliveries of such equipment shall be provided with a metal tag suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance March 8, 2006
 Examined by Donald [Signature]