



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Robert D. LiMandri, Acting Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 75-08-M

Manufacturer: Stafford Textiles Limited
2200 Lakeshore Blvd. West, Suite 308
Toronto, Ontario M8V 1A4
CANADA

Trade Name(s): Grandform 5099

Product: PVC-coated vinyl material
MEA Index #30 – Flex Sign

Pertinent Code Section(s): 27-499, 27-501, 27-506, 27-507, TPPN #11/99

Prescribed Test(s): RS 7-3 (NFPA 701-Test Method 2)

Laboratory: The Govmark Organization

Test Report(s): Report Nos. 2-69670-0, 2-69670-1, 2-69670-2, 2-68402-1, 2-68402-2RP issued September 6, 2007.

Description: Two stage laminator, which laminates 2-precalendered films with a fabric in between, is used for signs, Billboards and for indoor and outdoor installation. The material weighs 524 grams per meter square.

Terms and Conditions: The above-described material is accepted with the following conditions:

1. The acceptance of this material is limited to flame resistance.
2. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99.

3. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution.
4. All shipments and deliveries of such material shall be provided with a label, suitably placed, certifying that the material shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Note: In accordance with Section 27-131(d), all materials tested and accepted for use shall be subject to periodic retesting as determined by the Commissioner; and any material which upon retesting is found not to comply with Code requirements or the requirements set forth in the approval of the Commissioner shall cease to be acceptable for the use intended. During the period for such retesting, the Commissioner may require the use of such material to be restricted or discontinued if necessary to secure safety.

Final Acceptance May 9, 2008

Examined By Sean Derkshidan