



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 79-08-E

Manufacturer: Thermaco, Inc.
646 Greensboro Street
Asheboro, NC 27203

Trade Name(s): Trapzilla®

Product: Grease interceptors

Pertinent Code Section(s): Reference Standards RS 16: P105.4(d), P105.6(b), P105.7, P105.8

Prescribed Test(s): ASME A112.14.3-2000 & RS 16 – P105.4(d)(4)

Laboratory: IAMPO R&T Lab

Test Report(s): Report #907-07001 issued September 17, 2007 – Project No. 13485.

Description: Linear low-density, rotationally-molded polyethylene grease interceptor for separating and retaining free floating fats, oils and grease from food service establishment kitchen drain water.

Catalogue Description	Size (Inches) (Approx.)	Model No.
325 Pound Capacity Grease Interceptor with 75 GPM peak flow rating	36" x 36" x 38.5"	TZ-325
500 Pound Capacity Grease Interceptor with 150 GPM peak flow rating	36" x 36" x 49.5"	TZ-500

Notes: The "Trapzilla" trade name applies to both models, TZ-325 and TZ-500.

Terms and Conditions: The above kitchen grease interceptors are accepted on condition that:

1. All uses, locations and installations comply with the New York City Building Code, Subchapter 16, Reference Standard RS 16, specifically Section P105.4(d)(4), and the requirements of the Department of Environmental Protection.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance March 26, 2008.
Examined By Donald J. J.