



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 8-05-E Vol. 2

Manufacturer: System Sensor, 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): Honeywell

Product: Fire alarm equipment

Pertinent Code Section(s): RS 17-3, RS 4-6 (886-89-BCR)

Test(s): UL 864

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): Multiple Listing File No. S470, issued August 29, 2005, revised September 28, 2005

Description:

Honeywell Model No.	System Sensor Model No.	Description
TC909A1009	EM-1MI	Monitor Module
TC910N1007	EM-1SRI	Supervising Control Modules
TC910R1009	EM-1RI	Relay Module
TC909B1007	EM-1MMI	Monitor Modules

Terms and Conditions: The above equipment is accepted provided that:

1. All uses, locations, and installations comply with Article 17, Reference Standard RS-17 of the New York City Building Code, and the Electrical Code of the City of New York, applicable Fire Prevention Directives, and the manufacturer's instructions.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance December 14, 2006
Examined by Donald [Signature]