



# Report of Materials and Equipment Acceptance Division

NYC Department of Buildings  
280 Broadway, New York, NY 10007  
Patricia Lancaster, FAIA, Commissioner  
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

## MEA 83-03-E Vol. 2

**Manufacturer:** Goodman Manufacturing, 2550 North Loop West Suite 400, Houston, TX 77008.

**Trade Name(s):** Goodman

**Product:** Air cooled condensing units.

**Pertinent Code Section(s):** 27-770, 27-777.

**Prescribed Test(s):** RS 13-6 (ANSI B9.1), RS 13-11 (UL 1995).

**Laboratory:** Intertek, ETL Testing Laboratories Inc

**Test Report(s):** J20047666-001 dated April 30, 2001, revised February 3, 2005.

**Description** – The product covered by this report is an air-cooled condensing unit to be used as part of a split air conditioning system. The product is intended for outdoor installation. The unit is floor supported and is intended to be permanently connected to the supply source.

Model No.	Mfr.'s Specified Nominal Cooling Capacity BTUH
CRT24-1*	24,000
CRT30-1*	30,000
CRT36-1*	36,000
CRT42-1*	42,000
CRT48-1*	48,000
CRT60-1*	60,000
CRT18-1*	18,000

**Note:** \* with additional suffix.

**Terms and Conditions:** That the above outdoor air-cooled condensing unit be accepted under the following conditions:

1. All equipment shall be furnished with permanently affixed metal tags stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.
3. All shipments and deliveries of such equipment shall be accompanied by a metal tag, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 5/8/06

Examined by Supant. Prasad