



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 83-03-E Vol. 3

Manufacturer: Goodman Mfg. Company, L.P., 2550 North Loop West, Suite 400, Houston, TX 77092

Trade Name(s): Goodman, Amana, GMC, Janitrol

Product: Air-cooled condensing units

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-11B (ANSI B9.1), RS 13-11A (UL 1995)

Laboratory: Intertek, ETL Testing Laboratories, Inc.

Test Report(s): No. 3023184-001, dated December 17, 2002

Description: Air-cooled condensing units to be used as part of a split-air conditioning system. The product is intended for outdoor installation and connected by the installer to an indoor evaporator. The condensing unit is floor-supported and intended to be permanently connected to the supply source. The evaporator unit is duct-connected and intended to be permanently connected to the supply source.

Model No.	Mfr.'s Specified Nominal Cooling Capacity (Tons)
GSC100903**	7.5
GSC100904**	7.5
GSC101203**	10.1
GSC101204**	10.1

Note: * - Any alpha character (A-Z).

Terms and conditions: The above-described air-cooled condensing units are accepted under the following conditions:

1. Units shall use only Refrigerant R-22.
2. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without a damper, or (b) dampers and shutter within the system that shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
4. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
5. Approval of all electrical equipment, apparatus, materials, and devices shall be obtained from the Department's Electrical Advisory Board before installation.
6. Units shall be used in compliance with the Energy Conservation Construction Code of New York State.

Final Acceptance 10/11/06
Examined By [Signature]