

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, F.A.I.A., Commissioner
MEA 83-04-E

Report of Material and Equipment Acceptance Division

Manufacturer – Fire Products International, Ltd., 6988 Venture Street, BC Canada V4G 1H4.

Trade Name(s) – Fire Products.

Product – Factory built woodburning fireplaces.

Pertinent Code Section(s) – 27-848.

Prescribed Test(s) – RS 14-21 (UL1482), RS 14-20 (UL737).

Laboratory – Omni Test Laboratories Inc.

Test Report(s) – Project No. 219-5-03-2 dated February 2003.

Description –

Individual Products	Model Number(s)	Test Report #
All units below are Woodburning Units		Test Report
Medium Freestanding Woodstove 28-1/8" H x 24" W x 27-3/8" D Efficiency 77% Max. BTU: 75,000	F2400M, S2400M	OMNI-Test Lab 219-S02-2
Large Freestanding Woodstove - Step Top 33.2" H x 28" W x 25" D Efficiency 71% / Max. BTU: 80,000	S3100L	Warnock Hersey 476-1802-00 6623 - Feb. 1993
Medium Wood Fireplace Insert 22-3/4" H x 34-1/4" W x 22-7/8" D Efficiency 77% / Max. BTU: 75,000	I2400M	OMNI-Test Lab 219-S-03-2
Hampton Freestanding Woodstove 28-3/4" H x 27" W x 16-1/8" D Efficiency 74% / Max. BTU: 45,500	H300	OMNI-Test Lab 219-S-04-2

Recommendation - That the above described factory-built fireplaces, be accepted for use for the installation of decorative heating appliances and burning of wood only, for supplemental heating and decorative purposes. The installation of the above described units shall be in accordance with listing laboratories specifications, manufacturer's supplied instructions and Section 27-848 of the Building Code. Furthermore, the unit shall be vented in accordance with Section 27-856 of the Building Code. All shipments and deliveries of such equipment shall be provided with a laboratory label and a permanent tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance 5/28/04

Examined By Shyam