

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of the Material and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner
MEA 86-03-E

Report of Material and Equipment Acceptance Division
Manufacturer – IceQube, Inc. 911 South Main Street, Greentburg, PA. 15601.

Trade Name – Ice-Qube.

Product – Self-contained air conditioning units.

Pertinent Code Section(s)-27-770, 27-777.

Prescribed Tests - RS 13-12(UL484).

Laboratory – Underwriters Laboratories Inc.

Test Reports – File SA12062, dated February 2, 2000, revised February 15, 2002.

Description – Self-contained air conditioning units, model IQ, designed for indoor or outdoor installation. R-22 is the refrigerant used for the system. Unit consists of hermetic sealed compressor, air cooled condenser with fan and safety controls. Units, with model numbers and nominal cooling capacities, are listed below.

PRODUCT COVERED:

USL, CNL: Electronic control equipment air conditioners, Model IQ, followed by 1000V, 1200VS, 1500VS, 1800TS, 1800VS, 2200VS, 2300TS, 2500T, 2500TS, 2500TSHA, 2500V, 3000VS, 3500V, 3800VS, 4000T, 4000TS, 4000V, 4000V16HA, 5000T, 5000V, 5000V16, 5000V16HA, 6000T, 6000V16, 6000V16HA, 8000V16, 8000VHA, 10000V, 12000V, 14000V, 17000V, 20000V, 1200VXS, 1500VXS, 1800VXS. Models may also be prefixed XP1 or XP2.

The units cooling capacities vary from 1,000 BTUH to 20,000 BTUH.

Recommendation - That the above described self-contained air cooled condensing units be accepted for indoor or outdoor installation, when utilizing refrigerant R-22, under the following conditions:

1. All shipments and deliveries of such equipment shall be accompanied by a metal tag, certifying that the equipment shipped or delivered are equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
2. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance

5/12/03

Examined by

Shyam. K. Sarda