



NYC Department of Buildings  
 280 Broadway, New York, NY 10007  
 Patricia Lancaster, FAIA, Commissioner  
 (212) 566-5000, TTY: (212) 566-4769

## Report of Materials and Equipment Acceptance Division

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

### MEA 87-01-E Vol. 4

**Manufacturer:** System Sensor, A Div. of Honeywell, Int'l., 3825 Ohio Avenue, St. Charles, IL 60174

**Trade Name(s):** Mircom

**Product:** Fire alarm equipment

**Pertinent Code Section(s):** Subchapter 17 and Reference Standard 17

**Prescribed Test(s):** UL 864

**Laboratory:** Underwriters Laboratories, Inc.

**Test Report(s):** UL Multiple Listing File No. S5434, issued January 17, 2001 and revised May 23, 2007.

**Description:** System Sensor's control unit accessories as follows:

System Sensor Model No.	Mircom Model No.	Description
M500R	MIX-M500R	Relay Control Module
M500S	MIX-M500S	Supervised Control Module
M501M	MIX-M501M	Mini-monitor Module
M502M	MIX-M502M	Analog Addressable-initiating monitor Module

**Terms and Conditions:** The above units are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with the provisions of New York City Building Code, specifically Subchapter 17 and with Reference Standard RS 17-3. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL standard.
2. These units shall be used with compatible UL-listed and MEA-approved fire control panels. The compatibility must be specified or determined by a UL test report or the Engineer of Record.
3. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance July 17, 2007  
Examined By Donald [Signature]