

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A; Commissioner

MEA 88-03-E
Report of Material and Equipment Acceptance Division

Manufacturer - Simplex Time Recorder Co., 1 Simplex Plaza, Gardner, MA 01441-0001.

Trade Name - Pyro-Chem.

Product - Fire Alarm Equipment.

Pertinent Code Section - Reference Standard RS-17.

Prescribed Tests - UL 38, UL 268, UL 464, UL 864, UL 1481 and UL 1971.

Laboratory - Underwriters Laboratories, Inc.

Test Reports - Multiple Listing File No. S6568 and S6567 dated October 16, 2002.

Description	Simplex Model No.	Pyro-Chem Model No.
Notification Appliance Circuit	4009-9201, 4009-9301	Triton Ext. 551472, 551473
Fire Alarm Control Unit	4010-9102, 4010-9202	Triton RPA 551454, 551461

Recommendation - That the above units be accepted on condition that all uses, configurations, arrangements and functions, locations and installations comply with the New York City Building Code, specifically Subchapter 17 and Reference Standard RS 17-3 through 17-3C, inclusive as applicable, including the NFPA 11, 11A, 12, 12B, 13, 14, 15, 17, 70 and 72, UL 38, 268, 464, 521, 864, 1481, and 1971 Listings, manufacturer's instructions, the Fire Prevention Information Bulletins, and with the Electrical Code of the City of New York and on further condition that:


1. The connection of security/burglar devices and equipment to that submitted for acceptance for fire alarm usage under this MEA application is prohibited within New York City. Such equipment and devices shall be so permanently labeled.
2. Since fiber optics is not recognized by the New York City Building Code then the method of allowing any fiber optic transmitters and receivers for communication between 4009-9201 and 4009-9301 Notification Appliance Circuits (NACs) and with only Simplex Fire Alarm Control Panels shall be prohibited.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying the equipment shipped or delivered is equivalent to those tested and accepted for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance

September 11, 2003

Examined by

A handwritten signature in black ink, appearing to be "Donald J. [unclear]", written over a horizontal line.