



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
 280 Broadway, New York, NY 10007
 Patricia Lancaster, FAIA, Commissioner
 (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 9-06-E

Manufacturer: MITSUBISHI ELECTRIC HVAC

Trade Name(s): MR. SLIM M&P SERIES

Product: HEAT PUMP UNITS

Pertinent Code Section(s): 27-770, 27-777

Prescribed Test(s): RS 13-6 (ANSI B9.1), RS13-11 (UL 1995)

Laboratory: INTERTEK TESTING SERVICES

Test Report(s):

Description – Heat pump system. Units consist of an indoor unit and a matching outdoor unit which to be connected electrically and by refrigeration lines when installed. This product is installed. This product is intended to be permanently connected to the power source.

Indoor	Outdoor	Manufacturers Specified Nominal Cooling Capacity BTUH	Manufacturer Specified Nominal Heating Capacity BTUH
MSH09	MUHO9	8,500	9,000
12	12	12,300	12,000
15	15	14,300	15,000
17	17	15,900	17,000
24	24	24,000	24,000

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992. The Bureau of Fire Prevention has no objections Letter dated

Terms and Conditions: That the above described split system heat pump units, be accepted, when utilizing Refrigerant R-22, under the following conditions:

1. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without a damper or, (b) dampers and shutters within the system shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.
2. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in Section 27-131 of the Building Code.
3. Such equipment shall meet the requirements of Section 27-131, noise control of mechanical equipment, subdivision 4, as to maximum sound levels permitted, when located within 100 feet of any dwelling unit window.
4. A tag must be permanently affixed to the equipment stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770, as to maximum sound levels permitted for exterior mechanical equipment.
5. Approval of all electrical equipment , apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance

3/11/06

Examined by

Shyam M. Goonaw