



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 9-07-E

Manufacturer: System Sensor, Unincorporated Division of Honeywell International Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): System Sensor

Product: Fire alarm equipment

Pertinent Code Section(s): Subchapter 17 and Reference Standard RS17

Prescribed Test(s): UL 268A

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S911, Project 02NK6263, issued March 28, 2002, revised January 26, 2006

Description:

System Sensor Model Nos.	Description
DH400ACDCP	Duct Detector
DH400ACDCPX	Duct Detector

Pursuant to "Promulgation of the Rules relating to Material and Equipment Application Procedures" dated November 5, 1992, the Bureau of Fire Prevention has no objections Letter dated July 13, 2007, F.P. Index #0701015B.

Terms and Conditions: The above duct detectors are accepted on condition that:

1. All uses, configurations, arrangements and functions, application and installations comply with all applicable provisions of New York City Building Code, specifically with Subchapters 13 & 17, and Reference Standard RS 17-3. Further, the installation shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL standard.
2. The installation of above duct detectors shall provide for verification of air flow from the duct to the detector.
3. The detectors shall be used only with compatible and MEA-approved/accepted control panels and accessories.
4. Periodic maintenance and sensitivity tests of all detectors shall be conducted in accordance with the regulations of the Fire Department.
5. UL-listing requirements and manufacturer's maintenance procedures shall be complied with.
6. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance July 31, 2007
Examined By Donald [Signature]