



Report of Materials and Equipment Acceptance Division

NYC Department of Buildings
280 Broadway, New York, NY 10007
Patricia Lancaster, FAIA, Commissioner
(212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 9-08-E

Manufacturer: System Sensor, Unincorporated Division of Honeywell International, Inc., 3825 Ohio Avenue, St. Charles, IL 60174

Trade Name(s): Notifier

Product: Fire alarm equipment
MEA Index 280 – Fire Alarm Equipment

Pertinent Code Section(s): Subchapter 17 & Reference Standard RS 17

Prescribed Test(s): §27-969 (UL 864)

Laboratory: Underwriters Laboratories, Inc.

Test Report(s): UL File S3705, Project 07CA08300 issued December 20, 2007.

Description: The following models, FCM-1-REL and FCM-1-RELA, are intended for releasing applications with MEA-approved Notifier control panel NFS2-3030.

Model No.	Description
FCM-1REL, FCM-1RELA	Release control modules

Terms and Conditions: The above units are accepted under the following conditions:

1. All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Building Code, specifically Subchapter 17 and Reference Standard RS 17-3. Further, the installation of these modules shall be in accordance with the manufacturer’s recommendation and UL Standard 864.

2. These modules shall be connected to compatible, listed and approved control panels only.
3. Underwriters Laboratories, Inc.'s listing requirements and limitations shall be complied with.
4. All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and accepted for use, as provided in Section 27-131 of the New York City Building Code.

Final Acceptance February 6, 2008

Examined By Donald [Signature]