

CITY OF NEW YORK  
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 90-03-M  
Report of Material and Equipment Acceptance Division

Manufacturer – Julius Heywinkel GmbH. Heywinkelstrasse 1, Bramsche Germany 49565.

Trade Name(s) – Heytex 3512.

Product - PVC coated fabric for flexsign.

Pertinent Code Section(s) - 27-499, 27-501, 27-507, and TPPN #11/99.

Prescribed Test(s) - RS 7-3 [NFPA 701 (Test Method 2)].

Laboratory – SGS U.S. Testing Company.

Test Report(s) – Report No. 174245-04 dated February 14, 2003.

Description – Flexsign material Heytex 3512 is PVC coated polyester fabric blackout sign for inside and outside banners and signs. The materials has a nominal weight of 22.4 oz./square yard.

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April 25/03

Examined By S. Derf... ..