

CITY OF NEW YORK
DEPARTMENT OF BUILDINGS

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

MEA 91-03-M
Report of Material and Equipment Acceptance Division

Manufacturer – Julius Heywinkel GmbH. Heywinkelstrasse 1, Bramsche Germany 49565.

Trade Name(s) – Heytex 6471.

Product - PVC coated fabric for flexsign.

Pertinent Code Section(s) - 27-499, 27-501, 27-507, and TPPN #11/99.

Prescribed Test(s) - RS 7-3 [NFPA 701 (Test Method 2)].

Laboratory – SGS U.S. Testing Company.

Test Report(s) – Report No. 174245-03 dated February 14, 2003.

Description – Flexsign material Heytex 6471 is PVC coated polyester fabric frontlit sign for inside and outside banners and signs. The materials has a nominal weight of 13 oz./square yard.

Recommendation - That the above material be accepted as meeting the flame resistance requirements of Section 27-506 and 27-507 of the Building Code, for use on flex signs. The acceptance of this material is limited to flame resistance only. Structural and other requirements shall be in accordance with pertinent Building Code provisions and Technical Policy and Procedure Notice #11/99. All installations, uses and locations shall be in accordance with the New York City Building Code, specifically with Section 27-499 and 27-501, and the Zoning Resolution. All shipments and deliveries of such materials shall, in addition, be accompanied by a tag, certifying that the materials shipped or delivered are equivalent to those tested and acceptable for use, as provided for in Section 27-131 of the Building Code.

Final Acceptance April/25/03

Examined By S Derkshidan