

Report of Materials and Equipment Acceptance Division

NYC Department of Buildings 280 Broadway, New York, NY 10007 Patricia Lancaster, FAIA, Commissioner (212) 566-5000, TTY: (212) 566-4769

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use subject to the terms and conditions contained herein.

MEA 95-04-E Vol. 2(Correction)

Manufacturer:	System Sensor, Unicorp. Division of Honeywell, Intl. Inc. 3825 Ohio Avenue, St. Charles, IL 60174			
Trade Name(s):	Silent Knight, 7550 meridian circle, maple grove, MN. 55369			
Product:	Fire Alarm Equipment.			
Pertinent Code Section(s):	Subchapter 17 and Reference Standard RS17			
Prescribed Test(s):	UL 268			
Laboratory:	Underwriters Laboratories, Inc. (UL)			
Test Report(s):	UL Multiple Listing file S6173, issued July 21, 2005, revised January 10, 2006.			

System Sensor Model No.	Silent Knight Model No.	Description
FSB-200	IDP-BEAM	Beam Detector
FSB-200S	IDP-BEAM-T	Beam Detector

Terms and Conditions: The above units be accepted on condition that all uses, configurations, arrangements and functions, application and installations shall comply with New York City Building Code, specifically Subchapter 17, and Reference Standard RS17-3 through RS17-3C. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL Standard. Periodic maintenance and sensitivity tests where required shall be conducted in accordance with the regulations of the Fire Department.

All shipments and deliveries of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided in Section 27-131 of the Building Code.

Final Acceptance_	June	27	, 20	006.
Examined By	Dra	la	A	Del
L	/		14	B