

**CITY OF NEW YORK
DEPARTMENT OF BUILDINGS**

Pursuant to Administrative Code Section 27-131, the following equipment or material has been found acceptable for use in accordance with the Report of Materials and Equipment Acceptance (MEA) Division.

Patricia J. Lancaster, A.I.A., Commissioner

**MEA 96-02-E
Report of Material and Equipment Acceptance Division**

Manufacturer – Glomar Technologies Incorporated, 150 Britannia, Mississauga, Ontario Canada L4Z 2A4.

Trade Name(s) – Compax.

Product – Air conditioners.

Pertinent Code Section – 27-770, 27-777.

Prescribed Test(s) - RS 13-11 (UL 1995).

Laboratory – CSA International.

Test Report(s) – No. 1053558, dated May 14, 2002.

Description – Air conditioning units indoor use, as tabulated below. Cooling section comprises hermetically sealed compressors, air cooled condenser, evaporator coil with blower and safety controls, and hydronic heating. R-22 is the refrigerant used for the system.

Model No.	Mfr.'s Specified Nominal Cooling Capacity BTUH	Mfr.'s Specified Nominal Heating Input BTUH
IK008A,B	8,100	8,600
IK010A,B	10,200	8,900
IK012A,B	12,500	9,700

Recommendation - That the above described heating/cooling unit, be accepted for indoor installation only, under the follows conditions:

1. If utilized for residence heating, the circulatory air system shall have (a) one register or grille without closable shutters and the duct leading thereto shall be without a damper or, (b) dampers and shutters within the system shall be constructed or controlled so as to prevent closure beyond 80 percent of the gross duct area at all times.

2. All shipments and deliverers of such equipment shall be provided with a metal tag, suitably placed, certifying that the equipment shipped or delivered is equivalent to that tested and acceptable for use, as provided for in section 27-131 of the Building Code.
3. All equipment shall be furnished with a permanently affixed metal tag stating that if installed in New York City within 100 feet of any dwelling unit window, there shall be compliance with all provisions of Section 27-770 as to maximum sound levels permitted for exterior mechanical equipment.
4. Approval of all electrical equipment, apparatus, materials and devices shall be obtained from the Bureau of Electrical Control before installation.

Final Acceptance 6/10/02
Examined by Shyam S. Meena