



ROOF

6TH FLOOR

5TH FLOOR

4TH FLOOR

3RD FLOOR

2ND FLOOR

1ST FLOOR

CELLAR

MIN. 15'-0"

2-HOUR VOICE COMMUNICATION
CABLE INTEGRITY SYSTEM IN
CONDUIT

IS 1-HOUR RATED CONSTRUCTION
CLOSETS ACCEPTABLE FOR THIS
DGP HOUSING?

DGPs LOCATED IN 1-HOUR RATED
ELECTRICAL CLOSET WITH SPRINKLER
PROTECTION. (TYPICAL) CONFORMS TO
NFPA 72-2010 SECTION 24.3.5.4.1

FCC
BATT BATT

CLOSET



80 Pine Street
New York NY 10005
Tel. 212.530.9300
Fax. 212.269.5894

Title	CODE INTERPRETATION
Date	FEBRUARY 23, 2017
Checked by	BPW
Drawn by	EF
Sketch No.	ESK-002
Scale	NTS