



Monthly Accident Details: January - June, 2015

Incident Date	Borough	Address Number	Street	Fatalities	Injuries	EOC Final Description	DOB Action	ECB Violation Numbers	DOB Violation Numbers	Permit	Permit No	Incident Type	Owner's Name	Contractor Name
1/5/2015	Queens	31-25	NEWTOWN AVENUE	0	2	A section of a solid plywood fence blew over injuring two pedestrians. The pedestrians were taken to the hospital. DOB issued a violation and stop work order.	ECB Violation	#35035714J35035715L				Scaffold/Shed/Fence/Shoring/Installation	3125LLC	
1/9/2015	Manhattan	35	WEST 15 STREET	0	1	A plumber was hit in the face by pressurized water while tightening a three inch pipe.	ECB Violation	#35110252L				Material Fall	NOT ON FILE	
1/12/2015	Manhattan	252	EAST 57 STREET	0	1	The Site Safety Manager reported to DOB that a worker dropped a four foot long, ten inch cast iron pipe on his leg. The worker left the site to go to the doctor.	No Dispatch					Material Fall	NEW YORK CITY EDUCATIONAL CONS	
1/13/2015	Manhattan	552	West 24 Street	0	1	The Site Safety Manager reported to DOB that a worker cut his hand on a skill saw. The worker was transported to the hospital in a taxi.	No Dispatch					Other Construction Related Incidents	FEDERAL EXPRESS CORPORATION	
1/15/2015	Brooklyn	579	VAN BUREN STREET	0	1	A worker sustained severe injury to his leg when the foot of a used for scaffold operations, fell approximately ten feet over the foundation wall. DOB issued violations.	ECB Violation	#34999406H34999407J34999408L		New Building	320582140	Mechanical Construction Equipment	BROADWAY VAN BUREN PROPRTIES	Bayport Construction Corp
1/15/2015	Manhattan	605	WEST 129 STREET	0	1	The Site Safety Manager reported to DOB that a welder was splashed when welding and went to the doctor complaining that his eyes were bothering him.	No Dispatch					Other Construction Related Incidents	TRUSTEES OF COLUMBIA UNIVERISIT	
1/16/2015	Manhattan	1107	BROADWAY	0	1	The Site Safety Manager reported to DOB that a worker felt a pinched nerve in his neck while moving a mini container. An ambulance was called.	No Dispatch					Other Construction Related Incidents	MSWG 1107 BROADWAY OWNER LLC	
1/17/2015	Queens	155-28	LINDEN BOULEVARD	0	1	A worker sustained a cut arm when he slipped off a ladder.	ECB Violation	#35117877N	011715CNET01			Worker Fall	BRUNEAU, TANIA	
1/19/2015	Manhattan	135	WEST 52 STREET	0	1	The Site Safety Manager reported to DOB that a piece of plywood fell on a worker's leg when he reached out behind an electrical outlet.	No Dispatch					Material Fall	135 WEST 52ND STREET OWNER LLC	
1/19/2015	Manhattan	559	WEST 23 STREET	0	1	The Site Safety Manager reported to DOB that a worker slipped and fell off a ten foot ladder while trying to get a 2 1/4. An ambulance was called.	No Action Necessary			NEW BUILDING	103715383	Worker Fall	N18 PROPERTIES, LLC	K S K CONSTRUCTION GROUP
1/19/2015	Manhattan	559	WEST 23 STREET	0	1	A worker was struck on his leg by a piece of sheetrock while moving the sheetrock up a loading dock ramp on an 'A' frame. The worker was taken to the hospital by ambulance.	No Action Necessary					Material Fall	HUNTERS POINT SOUTH HOUSING DE	
1/20/2015	Queens	Jan-50	50 AVENUE	0	1	While using a hydraulic jack lift to load formwork onto a truck at the loading platform, the load became unstable and fell onto a worker approximately four feet below.	ECB Violation	#35117991H				Material Fall	50 WEST DEVELOPMENT LLC	
1/21/2015	Manhattan	50	WEST STREET	0	1	A worker was tripped in a trench being dug to access a broken stand pipe, when the shoring gave way. The worker was removed and taken to the hospital.	ECB Violation	#3511322M3511322J35117979Y35117980L	01215CERLP02_03_3M02.03			Excavator/Soil Work	NOT ON FILE	
1/21/2015	Manhattan	413	GRAND STREET	0	1	A contractor was fatally injured when he fell into an elevator shaft. The contractor reached for and missed a post on a gantry so he could lean over and look below. The gantry did not extend to the area from which the contractor fell.	ECB Violation	#35121044K	1215CNCM02	OT	122003900	Worker Fall	130 WEST 70 LLC	THE DRAGOTTA GROUP LLC
1/21/2015	Manhattan	130	WEST 70 STREET	1	1	The Site Safety Manager reported to DOB that a worker cut his finger when the grinder he was using to cut steel kicked back. A co-worker took the injured worker to the emergency room.	No Dispatch					Other Construction Related Incidents	HOST MARRIOTT, L.P.	
1/22/2015	Manhattan	139	WEST 52 STREET	0	1	A civilian van driver was struck by glass and the van roof was damaged when a piece of ornamental stone fell from the eleventh floor onto the roof of the van parked on the street beside the sidewalk shed.	ECB Violation	#35117502R	012215CERDF03	Alt 2	121908560	Scaffold/Shed/Fence/Shoring/Installation	730 RIVERSIDE DRIVE, LLC	JW Development Holdings L
1/22/2015	Manhattan	730	RIVERSIDE DRIVE	0	1	A worker fell approximately twenty feet from the third tier of a pipe scaffold. The worker was taken to the hospital by ambulance. DOB issued violations and a stop work order.	ECB Violation	#35121120M35121128H35121129J35121126Y35121127X				Worker Fall	NEW YORK CITY SCHOOL CONSTRUCT	
1/23/2015	Queens	39-07	57 STREET	0	1	A worker fell down a flight of stairs injuring his knee. No construction was occurring in the stair area. The worker was taken to the hospital. The stairs had handrails and no obstructions were observed. No DOB action was necessary.	No Action Necessary					Worker Fall	TRUSTEES OF COLUMBIA UNIVERISIT	
1/29/2015	Manhattan	605	WEST 129 STREET	0	1	The Site Safety Manager reported to DOB that an electrician cut his finger with a hand saw while cutting pipe. EMS was called.	No Dispatch					Other Construction Related Incidents	TRUSTEES OF COLUMBIA UNIVERISIT	
2/2/2015	Manhattan	605	WEST 129 STREET	0	1	The Site Safety Manager reported to DOB that a worker injured his shoulder when he miss stepped and fell off a ladder. An ambulance was called.	No Action Necessary					Other Construction Related Incidents	30 PARK PLACE RESIDENTIAL LLC	
2/3/2015	Manhattan	99	CHURCH STREET	0	1	An electrical worker fell approximately four feet from a ladder due to ice conditions. The worker was taken to the hospital in stable condition. DOB issued a violation and stop work order.	ECB Violation	#35121138L				Worker Fall	BRK GARAGE CO	
2/4/2015	Manhattan	430	WEST 15 STREET	0	1	A worker fell through the marble landing from the sixth floor to the fifth floor during demolition of the building. The worker was taken to the hospital with unknown injuries.	ECB Violation	#35117451X	020515CNERW01	DM - FULL DEMOLITION	121921091	Worker Fall	HFZ KIK 30TH STREET OWNER LLC	RED HOOK CONST GROUP-IL
2/5/2015	Manhattan	3	WEST 29 STREET	0	1	DOB issued violations.	ECB Violation	#35120863J35120864L35120865N35120866P35120867R				Other Construction Related Incidents	24TH STREET LIC LLC	
2/6/2015	Queens	41-42	24 STREET	0	1	The Site Safety Manager reported to DOB that a worker was splashed in the eyes by an alcohol based solvent while he was opening the bottle.	ECB Violation	#35120863J35120864L35120865N35120866P35120867R				Other Construction Related Incidents	24TH STREET LIC LLC	
2/6/2015	Queens	41-42	24 STREET	0	1	A worker was struck by plywood from the pipe scaffold after pushing on one of the scaffold frames. The cross braces of the scaffold frame had been moved to make room for equipment and material to be delivered through the service entrance and was not replaced prior to the worker exiting the building and pushing on the frame. The worker was transported to the hospital. DOB issued a violation.	ECB Violation	#35120863J35120864L35120865N35120866P35120867R				Other Construction Related Incidents	24TH STREET LIC LLC	
2/10/2015	Queens	Jan-55	BORDEN AVENUE	0	1	Site Safety Manager reported worker injured his hand. Worker took himself to the hospital.	ECB Violation	#35150592Y	021015CSSUM01	NB	420602217-01-NB	Scaffold/Shed/Fence/Shoring/Installation	NOT ON FILE	Monsieck Construction Inc
2/12/2015	Manhattan	21	WEST END AVENUE	0	1	The Site Safety Manager reported to DOB that a worker was struck in the face by a rib while performing form work. The worker went to urgent care and returned to work.	No Dispatch					Other Construction Related Incidents	RIVERSIDE CENTER PARCEL 2 BIT	
2/13/2015	Manhattan	252	EAST 57 STREET	0	1	A worker fell approximately twelve to fourteen feet when he slipped while ascending the ladder from the cellar to the first floor. The worker was taken to the hospital by ambulance. DOB observed no violating conditions. No DOB action was necessary.	ECB Violation					Material Fall	NEW YORK CITY EDUCATIONAL CONS	
2/13/2015	Manhattan	626	FIRST AVENUE	0	1	DOB issued violations to the face when struck by a construction site gate. The pedestrian was taken to the hospital by ambulance. DOB issued a violation and stop work order.	No Action Necessary					Worker Fall	616 FIRST AVENUE LLC	
2/14/2015	Brooklyn	59	FROST STREET	0	1	The Site Safety Manager reported to DOB that a worker fell off ladder and EMS was called.	No Action Necessary			NB	320588805	Worker Fall	88 RICHARDSON LLC	HLS BUILDERS CORP
2/17/2015	Brooklyn	122	VERONA STREET	0	1	The Site Safety Manager reported to DOB that a worker was struck by a beam while performing form work.	ECB Violation	#35120910N				Material Fall	RED HOOK 160 LLC	
2/18/2015	Manhattan	135	WEST 52 STREET	0	1	A worker slipped on ice. DOB issued a violation.	ECB Violation	#35121822Z				Worker Fall	135 WEST 52ND STREET OWNER LLC	
2/19/2015	Brooklyn	626	FLATBUSH AVENUE	0	1	A pedestrian sustained lacerations to the face when struck by a construction site gate. The pedestrian was taken to the hospital by ambulance. DOB issued a violation and stop work order.	ECB Violation	#35121456R		NB	320514760	Scaffold/Shed/Fence/Shoring/Installation	HUIJSON CBO FLATBUSH LLC	

Monthly Accident Details: January - June, 2015

Incident Date	Borough	Address Number	Street	Fatalities	Injuries	EOC Final Description	DOB Action	ECB Violation Numbers	DOB Violation Numbers	Permit	Permit No	Incident Type	Owner's Name	Contractor Name
2/20/2015	Manhattan	180	6 Ave	0	1	The Site Safety Manager reported to DOB that a worker fell three feet from a step ladder and injured his arm. EMS was called.	No Dispatch					Worker Fall	QT SOHO Realty LLC, Walker Maloy & Company	
2/21/2015	Brooklyn	333	SCHERMERHORN STREET	0	1	A rigger in loading area was struck by falling rebar when the pulley broke causing the rebar to fall during the unloading process. The rigger was taken to the hospital by ambulance. DOB issued a violation and stop work order.	ECB Violation	#35121458K				Mechanical Construction Equipment	HUB ASSOCIATES, LLC	
2/23/2015	Brooklyn	250	ASHLAND PLACE	0	1	The Site Safety Manager reported to DOB that a worker slipped on the ice and an ambulance was called.	No Dispatch					Worker Fall	600 FULTON CORP	
2/23/2015	Manhattan	21	WEST END AVENUE	0	1	The Site Safety Manager reported to DOB that a worker slipped descending a ladder and injured his ankle. The worker went to the doctor on his own.	No Dispatch					Worker Fall	RIVERSIDE CENTER PARCEL 2 BIT	
2/24/2015	Brooklyn	620	ATLANTIC AVENUE	1	0	A worker was fatally injured when a load of steel trusses shifted during the unloading process and rolled onto the worker.	ECB Violation	#35121188J				Mechanical Construction Equipment	ARENA NOMNEE SUB B.	
2/26/2015	Manhattan	521	WEST 43 STREET	0	1	A worker miss stepped when entering an elevator. DOB found no violating conditions. No DOB action was necessary.	No Action Necessary					Worker Fall	NEW YORK CITY SCHOOL CONSTRUCT	
2/27/2015	Brooklyn	90	FURMAN STREET	0	1	A glazer was injured when supports failed causing the window he was installing to fall on him. The worker was taken to the hospital by ambulance with a possible leg fracture. DOB issued a violation and stop work order.	ECB Violation	#35122351P				Material Fall	BROOKLYN BRIDGE PARK DEVELOPME	
2/27/2015	Manhattan	1	7 AVENUE	0	1	A worker fell approximately six feet when he slipped on a ladder while performing form work. DOB issued violations and stop work order.	ECB Violation	#35122283M/35122286H				Worker Fall	WEST VILLAGE HOLDINGS LLC	
2/27/2015	Manhattan	21	WEST END AVENUE	0	1	A worker was taken to the hospital when dust got under his safety glasses while the worker was drilling holes in a slab to set plates used to install the curtain wall panels.	No Dispatch					Other Construction Related Incidents	RIVERSIDE CENTER PARCEL 2 BIT	
3/0/2015	Manhattan	50	WEST STREET	0	1	A mason injured his back while descending a scaffold. DOB issued violations and stop work order.	ECB Violation	#35122292Y				Worker Fall	50 WEST DEVELOPMENT LLC	
3/0/2015	Manhattan	530	WEST 33 STREET	0	1	The Site Safety Manager reported to DOB that a worker injured his back while welding. EMS was called.	No Dispatch					Other Construction Related Incidents	NOT ON FILE	
3/4/2015	Manhattan	132	WEST 27 STREET	0	1	A worker, carrying material from the hoist down a ramp, fell and injured himself. The worker was taken to the hospital by ambulance.	No Action Necessary					Worker Fall	132 WEST 27TH EQUITIES LLC	
3/4/2015	Manhattan	21	WEST END AVENUE	0	1	A worker slipped on a ramp while unloading a truck. DOB's inspector observed one throughout the ramp. The worker was taken to the hospital with head injuries. DOB issued a violation and stop work order.	ECB Violation	#35122284H				Worker Fall	RIVERSIDE CENTER PARCEL 2 BIT	
3/4/2015	Manhattan	50	WEST STREET	0	1	A worker fractured his arm when he fell while attempting to climb the rebar cage he was installing. The worker was taken to the hospital by the shop steward. DOB issued a violation and stop work order.	ECB Violation	#35122284H				Worker Fall	50 WEST DEVELOPMENT LLC	
3/9/2015	Queens	44-41	PURVES STREET	0	1	The Site Safety Manager reported to DOB that a worker injured his arm while installing duct work. EMS was called. No DOB action was necessary.	No Action Necessary			NB	420604359	Other Construction Related Incidents	PURVIS HOLDINGS LLC	HSD CONSTRUCTION LLC
3/11/2015	Manhattan	460	WASHINGTON STREET	0	1	The Site Safety Manager reported to DOB that an electrician tripped over his tools and cut his thumb. The electrician was taken to the emergency room for stitches.	No Dispatch	#35122377N/35122375J				Worker Fall	BRIDGE LAND WEST LLC	
3/11/2015	Manhattan	203	EAST 92 STREET	0	2	Two workers fell while working independently. One worker was installing rebar and fell approximately fifteen feet from the eighth to seventh floor. The second worker was between the seventh and eighth floor and fell approximately six feet. Both workers were taken to the hospital by ambulance with unknown injuries. DOB issued a violation and stop work order.	ECB Violation	#35122372Y/35122373X				Worker Fall	CARNEGIE PARK LAND HOLDING, LL	
3/12/2015	Manhattan	15	DESBROSSES STREET	0	1	A security guard fell approximately twelve feet from the ground floor to the bottom of the elevator pit.	No Dispatch			ALT	110360341	Worker Fall	SGN 443 GREENWICH STREET FEE O	443 Developer LLC
3/16/2015	Manhattan	150	CHARLES STREET	0	1	A worker complained of pain when a window tipped over and struck him in the leg, while he was pulling on extension cord. The worker was taken to the hospital by ambulance. DOB issued a violation.	ECB Violation	#35108661J				Material Fall	150 CHARLES STREET HOLDINGS, L	
3/16/2015	Manhattan	219	EAST 44 STREET	0	1	The Site Safety Manager reported to DOB that a worker poked his finger while holding a board sustaining possible fracture.	No Dispatch					Material Fall	CWC INC.	
3/16/2015	Manhattan	860	WASHINGTON STREET	0	1	A worker was struck by a piece of plywood during stripping operation. The worker was taken to the hospital by a follow worker with a minor cut. DOB issued violations and stop work order.	ECB Violation	#35108608K				Material Fall	860 WASHINGTON STREET LLC	
3/17/2015	Brooklyn	REPORTED	ASHLAND PLACE	0	1	A worker was struck by a stringer that deflected after falling on the floor. The worker was taken to the hospital.	ECB Violation					Material Fall	600 FULTON CORP	
3/17/2015	Queens	37-01	138 STREET	0	1	A worker was struck by a piece of concrete while putting on his protective equipment in an area where forms were being stripped. The worker was taken to the hospital by ambulance. DOB issued a violation and stop work order.	ECB Violation	#35108617M				Material Fall	FLUSHING COMMONS PROPERTY OWNE	
3/18/2015	Manhattan	1	7 AVENUE	1	0	A pedestrian was fatally injured when struck by a section of plywood from a construction fence. DOB issued violations and stop work order.	ECB Violation	#35108670L/35108671N/35108672P				Other Construction Related Incidents	WEST VILLAGE HOLDINGS LLC	
3/18/2015	Manhattan	19	PARK PLACE	0	1	After the owner's representative accessed the twenty-second floor by using the hoist without an operator, accompanied by two workers who remained on the hoist, the owner's representative was found on a pile of re-shores complaining of back pain. EMS transported the injured representative to the hospital. DOB issued violations and stop work order.	ECB Violation	#35122501L				Mechanical Construction Equipment	ABN REALTY,	
3/19/2015	Manhattan	10	EAST 15 STREET	0	1	A worker sustained an injury to his hand during drilling operation. The worker was taken to the hospital. No violations issued at this time.	No Action Necessary					Worker Fall	NEW YORK CITY SCHOOL CONSTRUCT	
3/19/2015	Manhattan	232	SEVENTH AVENUE	0	1	The Site Safety Manager reported to DOB that a worker tripped on the ground as he was leaving the site and EMS was called.	No Dispatch					Other Construction Related Incidents	KARMELENA REALTY CO., LLC	
3/20/2015	Manhattan	99	CHURCH STREET	0	1	A worker on the fifteenth floor was struck by a Doka panel that fell approximately eight feet when a worker on the sixteenth floor lost control of the Doka panel while attempting to install it. The injured worker was taken to the hospital by ambulance with unknown injuries. DOB issued a violation and stop work order.	No Dispatch					Worker Fall	30 PARK PLACE RESIDENTIAL LLC	
3/20/2015	Manhattan	252	EAST 57 STREET	0	1	The Site Safety Manager reported to DOB that an electrician tripped on his wire and hit his forehead. An ambulance was called.	No Dispatch					Material Fall	NEW YORK CITY EDUCATIONAL CONS	
3/23/2015	Bronx	350	MARCONI STREET	0	1	The Site Safety Manager reported to DOB that an electrician tripped on his wire and hit his forehead. An ambulance was called.	No Dispatch					Worker Fall	HUTCH REALTY PARTNERS LLC	

Monthly Accident Details: January - June, 2015

Incident Date	Borough	Address Number	Street	Fatalities	Injuries	EOC Final Description	DOB Action	ECB Violation Numbers	DOB Violation Numbers	Permit	Permit No	Incident Type	Owner's Name	Contractor Name
3/23/2015	Manhattan	245	WEST 14 STREET	0	1	A worker fell and injured his knee when he slipped on ice accumulated on the roof. DOB issued a violation and stop work order. The Site Safety Manager reported to DOB that a worker tripped on a wire mesh ramp. DOB found no violating conditions during an inspection. No DOB action was necessary.	ECB Violation	#35122229L				Worker Fall	FIRST 14TH LLC	
3/23/2015	Manhattan	432	PARK AVENUE	0	1	The day after tripping, a worker fell pain and went to the hospital.	No Action Necessary					Worker Fall	NEW 56TH AND PARK (NY) OWNER	
3/24/2015	Manhattan	21	WEST END AVENUE	0	1	The Site Safety Manager reported to DOB that a worker fell approximately three feet from a ladder. EMS was called.	ECB Violation					Worker Fall	RIVERSIDE CENTER PARCEL 2 BIT	
3/24/2015	Manhattan	400	EAST 56 STREET	0	1	The Site Safety Manager reported to DOB that a worker cut himself on the knee with a grinder. The worker went to the hospital on his way for stitches.	No Action Necessary					Worker Fall	PLAZA 400 OWNERS CORP	
3/25/2015	Queens	39-07	57 STREET	0	1	A worker fell to the bottom of an elevator pit while moving a scaffold over the pit. The worker was transported to the hospital.	No Dispatch					Other Construction Related Incidents	NEW YORK CITY SCHOOL CONSTRUCT	
3/27/2015	Manhattan	29	EAST 22 STREET	0	1	The Site Safety Manager reported to DOB that a piece of sheetrock fell on top of a workers leg. EMS was called.	ECB Violation	#35127110R	32715CNETZ01			Worker Fall	NOT ON FILE	EMPIRE GENERAL CONTRACTIN
3/30/2015	Manhattan	1107	BROADWAY	0	1	The Site Safety Manager reported to DOB that two workers sustained concrete burns on their feet and were admitted to the hospital.	No Dispatch					Material Fall	MSAWG 1107 BROADWAY OWNER LLC	
3/30/2015	Manhattan	1283	YORK AVENUE	0	2	The Site Safety Manager reported to DOB that a worker was cut on his finger by a piece of glass. The worker was taken to the hospital by taxi.	ECB Violation	#35122311K				Other Construction Related Incidents	THE NEW YORK AND PRESBYTERIAN	
3/30/2015	Manhattan	129	WEST 52 STREET	0	1	A worker was injured when control of sheetrock was lost while the sheetrock was being moved from a truck to an A frame. The injured worker was taken to the hospital with a possible fractured ankle. DOB issued a violation and stop work order.	No Dispatch					Other Construction Related Incidents	135 WEST 52ND STREET OWNER LLC	
3/30/2015	Manhattan	855	6 AVENUE	0	1	A worker sustained injury to his arm when a section of plywood fell one story striking the worker. The worker was taken to the hospital by ambulance.	ECB Violation	#35108882N				Material Fall	855 MRU LLC	
3/31/2015	Manhattan	626	1 AVENUE	0	1	A worker was fatally injured when he fell approximately six stories. The worker was using a powered broom machine to finish the floor and stepped beyond the protection system that was setback five feet from the 0 edge. DOB issued violations and a stop work order.	ECB Violation	#35122999H				Material Fall	616 FIRST AVENUE LLC	
4/1/2015	Brooklyn	360	NEPTUNE AVENUE	1	0	The Site Safety Manager reported to DOB that an electrician injured his eyes from an electric arc. The electrician was taken to the hospital.	ECB Violation	35123041Y	040115EE105FM2	N/A	N/A	Other Construction Related Incidents	111 WEST 57TH LH LLC	N/A
4/1/2015	Manhattan	217	WEST 57 STREET	0	1	A worker injured his leg when struck by a waller being lowered along the outer edge of a pipe scaffold. The worker was taken to the hospital.	ECB Violation					Material Fall	BROADWAY 57TH/58TH RETAIL INVE	
4/2/2015	Manhattan	252	EAST 57 STREET	0	1	A concrete worker sprained his wrist when he tripped on rebar. The worker was sent home and returned the next day with a swollen wrist and was sent for X-rays.	No Action Necessary					Worker Fall	NEW YORK CITY EDUCATIONAL CONS	
4/2/2015	Manhattan	252	EAST 57 STREET	0	1	A plumber sustained a laceration to his hand when he attempted to move a dumpster and the dumpster wheel became lodged in a hole, pinning the plumber's hand between the dumpster and a wall. The plumber went to a medical treatment center for stitches.	ECB Violation					Other Construction Related Incidents	NEW YORK CITY EDUCATIONAL CONS	
4/4/2015	Manhattan	433	1 AVENUE	0	1	A pedestrian was struck by a wooden barricade installed to prevent public access to the courtyard. EMS was called.	No Action Necessary			NB	121181176	Scaffold/Shed/Fence/Shoring/Installation	NEW YORK UNIVERSITY	TURNER CONSTRUCTION COMPA
4/6/2015	Manhattan	1133	YORK AVENUE	0	1	The Site Safety Manager reported to DOB that a worker may have sustained broken ribs when the worker fell onto steel supports while using stairs. EMS was called.	No Action Necessary					Worker Fall	S.K.I. REALTY, INC.	
4/6/2015	Manhattan	19	9 AVENUE	1	0	A construction worker was fatally injured when a trench collapsed. The contractor excavated a fourteen feet deep trench for box pit installation. During construction of the box pit, the soil collapsed on the worker.	ECB Violation	#35118404H/35118405L/35118406L/35118407N/35118084P/35118090R/35118410Y		Air	121753058	Excavation/Soil Work	9TH AVENUE DELAWARE OWNER LLC	Harco Consultants corp
4/6/2015	Manhattan	56	LEONARD STREET	0	1	The Site Safety Manager reported to DOB that a worker handling load twisted his knee. EMS was called.	No Dispatch					Worker Fall	56 LEONARD LLC	
4/6/2015	Manhattan	860	WASHINGTON STREET	0	1	A security guard may have sustained a fractured ankle when a forklift ran over the his foot. The guard was taken to the hospital by ambulance. DOB issued a violation and stop work order.	ECB Violation					Mechanical Construction Equipment	860 WASHINGTON STREET LLC	
4/7/2015	Manhattan	331	MADISON AVENUE	0	4	Four workers were injured when the marble banister they were using as leverage gave way. The workers were 4' attempting to remove a chandelier from the ceiling.	ECB Violation	#35036532N /35036533P /35036534R	040715CERDL01,02,03			Material Fall	SLG 331 MADISON LLC	
4/7/2015	Manhattan	111	WEST 57 STREET	0	1	The Site Safety Manager reported to DOB that an electrician injured his eyes from an electric arc. The electrician was taken to the hospital.	ECB Violation	#35123041Y	040115EE105FM2	N/A	N/A	Other Construction Related Incidents	111 WEST 57TH LH LLC	N/A
4/7/2015	Manhattan	111	WEST 57 STREET	0	1	The Site Safety Manager reported to DOB that a worker injured his ribs with a core drill machine. EMS was called.	ECB Violation					Other Construction Related Incidents	111 WEST 57TH LH LLC	
4/8/2015	Bronx	1512	BOONE AVENUE	0	1	A worker was struck by a truck which when the worker entered the barricaded area while the truck was reversing. The worker sustained a bruised leg and was taken to the hospital by ambulance. DOB observed no violating conditions.	ECB Violation					Mechanical Construction Equipment	ALLIED WEST FARMS (NY) LLC	
4/8/2015	Manhattan	175	WEST 60 STREET	0	1	The Site Safety Manager Reported to DOB that a worker cut himself with a grinder and was taken to the hospital by EMS.	No Dispatch					Other Construction Related Incidents	WEST 60TH REALTY LLC	
4/9/2015	Manhattan	18	WEST 56 STREET	0	1	A worker injured his knee when he lost his balance while working on a makeshift platform passing material above. EMS was called. DOB issued a violation.	ECB Violation	#35122247P				Worker Fall	18 WEST 56 ST LLC	
4/9/2015	Manhattan	855	6 AVENUE	0	1	The Site Safety Manager reported to DOB that a carpenter injured his hand with a nail and EMS was called.	No Dispatch			NB	121331102	Other Construction Related Incidents	855 MRU LLC	GILBANE BUILDING COMPANY
4/9/2015	Queens	23-01	42 ROAD	0	2	Two workers were injured when panels used for form work fell striking the workers. The workers were passing the panels from the thirteenth floor to the fourteenth floor when the panels stacked in an upright manner became unstable and collapsed on the workers. One worker was transported to the hospital. The other worker was treated on site.	ECB Violation	#35125592Z				Material Fall	QPS 23-10 DEVELOPMENT LLC	
4/13/2015	Brooklyn	100	WILLOUGHBY STREET	0	1	The Site Safety Manager reported to DOB that a worker hurt his finger while pulling down the concrete sheet during concrete pouring operations. The worker went to the hospital in a cab.	No Dispatch					Other Construction Related Incidents	AVALON WILLOUGHBY WEST, LLC	

Monthly Accident Details: January - June, 2015

Incident Date	Borough	Address Number	Street	Fatalities	Injuries	EOC Final Description	DOB Action	ECB Violation Numbers	DOB Violation Numbers	Permit	Permit No	Incident Type	Owner's Name	Contractor Name
4/13/2015	Manhattan	111	WEST 57 STREET	0	1	The Site Safety Manager reported to DOB that a worker sustained a scrape while falling by a mini container and went to the hospital on his own.	No Action Necessary			ALT 2	140152313	Other Construction Related Incidents	111 WEST 57TH LH LLC	JDS Construction Group
4/13/2015	Manhattan	435	WEST 31 STREET	0	1	A worker lost his footing while installing rebar and received a laceration to his arm when he reached for the rebar. The worker was transported to the hospital for stitches. DOB observed no violating conditions.	No Action Necessary					Worker Fall	AMTRAK	
4/16/2015	Manhattan	50	WEST STREET	0	1	A worker was injured when the redwood power mixer he was using became unstable falling onto the worker. The worker was taken to the hospital in unknown condition. DOB issued a violation.	ECB Violation	#3510889EY				Mechanical Construction Equipment	50 WEST DEVELOPMENT LLC	
4/16/2015	Manhattan	215	CHRYSIE STREET	0	1	The Site Safety Manager reported to DOB that a worker slipped on a wet floor injuring his back. EMS was called. DOB observed no excess water during an inspection of the site. No DOB action was necessary.	ECB Violation					Worker Fall	NOT ON FILE	
4/16/2015	Manhattan	1	7 AVENUE	0	1	A worker fell approximately four feet off a ramp while moving sheet rock on an A-frame down the ramp. The worker was taken to the hospital with unknown injuries. DOB issued a violation and stop work order.	ECB Violation	#35121543P				Worker Fall	WEST VILLAGE HOLDINGS LLC	
4/16/2015	Brooklyn	140	SCHERMERHORN STREET	0	1	The Site Safety Manager reported to DOB that a worker was struck in the face by a post from the form work he was erecting slipped from his hand. EMS was called.	No Dispatch					Other Construction Related Incidents	71 SMITH STREET PROPERTY OWNER	
4/17/2015	Manhattan	6	PLATT STREET	0	1	The Site Safety Manager Reported to DOB that a worker cut his finger with a box cutter and went to the hospital for stitches.	No Dispatch			ot	122049899	Other Construction Related Incidents	LAM PLATT STREET HOTEL LLC	C & I PLUMBING CONSTRUCTI
4/20/2015	Manhattan	501	WEST 30 STREET	0	1	A worker fell through a hole on the twenty-ninth floor and landed on the twenty-eighth floor when the hole covering became dislodged. The worker suffered lacerations to his head and complained of pain in his right leg. The worker was taken to the hospital by ambulance. DOB issued a violation.	ECB Violation	#35109674Z				Worker Fall	NOT ON FILE	
4/20/2015	Manhattan	507	WEST 28 STREET	0	1	A worker fell off a platform approximately eighteen feet above ground level while performing rigging operations. The worker was wearing a harness and was tied off. The worker suffered possible fractured ribs when he came in contact with obstructions while suspended, while being suspended his body came in contact with obstructions. The worker was taken to the hospital by ambulance. DOB issued a violation and stop work order.	ECB Violation	#35109673R				Worker Fall	KADIMA TENTH AVENUE SPE LLC	
4/20/2015	Queens	42-09	28 STREET	0	1	An electrician was on an A-frame ladder working on a splitting box when he lost his footing and fell approximately six feet. The electrician suffered a head injury and was taken to the hospital by ambulance.	No Action Necessary					Worker Fall	NOT ON FILE	
4/21/2015	Brooklyn	71	SMITH STREET	0	1	The Site Safety Manager reported to DOB that a worker was struck in the head by a form being passed from one worker to another. The injured worker was taken to the hospital as a precaution.	No Dispatch					Material Fall	71 SMITH STREET PROPERTY OWNER	
4/22/2015	Manhattan	1283	YORK AVENUE	0	1	A worker was struck by waterproofing material that had caught fire. The worker used a fire extinguisher to put out the fire. The worker was treated by the onsite EMT.	No Dispatch					Material Fall	THE NEW YORK AND PRESBYTERIAN	
4/22/2015	Manhattan	380	MADISON AVENUE	0	1	A fireguard was struck by a heater that fell. The worker sustained possible fractured legs and was taken to the hospital by ambulance.	ECB Violation	#35122443M				Other Construction Related Incidents	650 MADISON OWNER LLC	
4/23/2015	Manhattan	50	WEST STREET	0	1	The Site Safety Manager reported to DOB that a worker tripped and went to the hospital on his own.	No Dispatch					Worker Fall	50 WEST DEVELOPMENT LLC	
4/23/2015	Manhattan	155	EAST 79 STREET	0	1	The Site Safety Manager reported to DOB that a worker injured his back while picking up a piece of marble. The worker was taken to the hospital by EMS.	No Dispatch					Other Construction Related Incidents	155 EAST 79TH STREET, LLC	
4/23/2015	Manhattan	15	RENWICK STREET	0	1	The Site Safety Manager reported to DOB that a worker was struck by a screw when the screw gun he was using slipped. The worker went to the hospital in a cab.	No Dispatch					Other Construction Related Incidents	IGGGP RENWICK LLC	
4/23/2015	Brooklyn	286	ASHLAND PLACE	0	1	A worker was struck by a bucket backing up. The worker was taken to the hospital by ambulance.	ECB Violation	#35122270N				Mechanical Construction Equipment	20 LAFAYETTE LLC	
4/27/2015	Brooklyn	336	FLATBUSH AVENUE EXTENSION	0	1	The Site Safety Manager reported to DOB that a carpenter pinched her hand between sheetrock and the wall while moving sheetrock on an A-frame. EMS was called.	No Dispatch					Other Construction Related Incidents	D C A S	
4/27/2015	Manhattan	1283	YORK AVENUE	0	1	The Site Safety Manager reported to DOB that a worker was struck on the hand by lumber being unloaded by another worker. The injured worker went to the stage center of the hospital.	No Dispatch					Material Fall	THE NEW YORK AND PRESBYTERIAN	
4/27/2015	Manhattan	220	CENTRAL PARK WEST	0	1	The Site Safety Manager reported to DOB that a worker injured his hand while pushing a container. The worker went to urgent care on his own.	No Dispatch					Other Construction Related Incidents	ALDEN OWNERS INC (THE)	
4/29/2015	Manhattan	151	WEST 34 STREET	0	1	The Site Safety Manager Reported to DOB that a worker cut his arm with a utility knife. The worker was taken to the hospital.	No Dispatch			OT	140313177	Other Construction Related Incidents		STRUCTURE TONE INC
5/1/2015	Brooklyn	1705	DEAN STREET	0	1	A worker was injured when the trench he was in collapsed. The worker was removed from the trench by FDNY and taken to the hospital by ambulance. DOB issued violations and a stop work order.	ECB Violation	#35103691H				Excavation/Soil Work	DEAN STREET PROJECT LLC	
5/1/2015	Manhattan	7	21ST STREET	0	1	The Site Safety Manager reported to DOB that a worker cut his leg while cutting plywood. EMS was called.	No Dispatch					Other Construction Related Incidents	7 WEST 21 LLC C/O FRIEDLAND PROPERTIES	
5/4/2015	Manhattan	41	EAST 22 STREET	0	1	A worker was struck in the back when someone fell during installation. The worker was taken for medical treatment and returned to work. DOB issued a violation and stop work order.	ECB Violation					Material Fall	45 EAST 22ND STREET PROPERTY L	
5/4/2015	Manhattan	111	WEST 57 STREET	0	1	The Site Safety Manager reported to DOB that a window weight fell on a worker's foot during removal of the window. The worker was transported to the hospital.	No Dispatch					Material Fall	111 WEST 57TH LH LLC	
5/4/2015	Manhattan	101	WEST 28 STREET	0	1	The Site Safety Manager reported to DOB that a worker sustained a cut to his arm and was taken to the hospital for stitches.	No Dispatch					Other Construction Related Incidents	815 NY LENDER LLC	
5/4/2015	Brooklyn	1511	BEDFORD AVENUE	0	1	The Site Safety Manager reported to DOB that a worker picking up garbage stepped on a rock and twisted his back. The worker called EMS.	No Dispatch					Worker Fall	1515 BEDFORD AVENUE REALTY LLC	
5/5/2015	Brooklyn	305	GRAND STREET	0	2	Two workers fell from a scaffold sustaining unknown injuries.	ECB Violation	#35131920K/35131921M/35131922Y	050915CSUW/B07 - CSUW/B09			Worker Fall	305 GRAND LLC	Brooklyn GC LLC
5/5/2015	Queens	131-07	40 ROAD	0	1	A worker was injured when his leg was pinned between a beam and a load of steel I-beams being hoisted by a crane. The worker was taken to the hospital. DOB issued a violation and stop work order.	ECB Violation					Mechanical Construction Equipment	NOT ON FILE	



Monthly Accident Details: January - June, 2015

Incident Date	Borough	Address Number	Street	Fatalities	Injuries	EOC Final Description	DOB Action	ECB Violation Numbers	DOB Violation Numbers	Permit	Permit No	Incident Type	Owner's Name	Contractor Name
5/7/2015	Queens	29-07	QUEENS PLAZA NORTH	0	1	The Site Safety Manager reported to DOB that debris fell from the third floor striking a child. The DOB inspector was unable to determine that the small injury on the child's arm was sustained at the site. No evidence of fallen debris was observed.	No Action Necessary					Material Fall	GRANITE QUEENS PLAZA LLC	
5/8/2015	Manhattan	1114	AVENUE OF THE AMERICAS	0	1	The Site Safety Manager reported to DOB that a worker fell approximately ten feet into the scuttle hole. FDNY and EMS was called to the site.	ECB Violation	#35131731L/35131732N	050815CSSU401-050815CSSU402	Alt 2	121984488	Worker Fall	1114 6TH AVENUE OWNER LLC	Hold Construction Corp
5/8/2015	Manhattan	35	WEST 15 STREET	0	1	The Site Safety Manager reported to DOB that a worker cut his thumb while cutting tile. The worker walked to the hospital.	No Dispatch					Other Construction Related Incidents	NOT ON FILE	
5/8/2015	Manhattan	530	WEST 33 STREET	0	1	The Site Safety Manager reported to DOB that a worker injured his finger while moving a material cart and EMS was called.	No Dispatch					Other Construction Related Incidents	NOT ON FILE	
5/8/2015	Manhattan	175	WEST 60 STREET	0	1	The Site Safety Manager reported to DOB that a worker injured his foot while unloading GWB. EMS was called.	No Dispatch					Other Construction Related Incidents	WEST 60TH REALTY LLC	
5/11/2015	Staten Island	7	NAVY PIER COURT	0	1	A worker fell approximately fifteen feet when he leaned on the vertical railing and the cables gave way. The worker was conscious with no visible laceration or fractures when taken to the hospital by ambulance.	ECB Violation					Worker Fall	HOMEPORT L LLC	
5/11/2015	Manhattan	823	1 AVENUE	0	1	The Site Safety Manager reported to DOB that an iron worker twisted his ankle while descending a ladder and EMS was called.	No Dispatch					Worker Fall	G-210 UNP REALTY, LLC	
5/11/2015	Brooklyn	1511	BEDFORD AVENUE	0	1	The Site Safety Manager reported to DOB that a worker injured his foot while moving a plank and stepped on a beam. EMS was called.	No Dispatch					Other Construction Related Incidents	1515 BEDFORD AVENUE REALTY LLC	
5/12/2015	Manhattan	20	EAST END AVENUE	0	1	A worker sustained a possible broken wrist and laceration to the face when he fell from a rebar cart. The worker was standing on the cart while passing rebar from the first floor to the second floor. The worker was taken to the hospital by ambulance.	ECB Violation					Worker Fall	20 EEA PARTNERS LLC	
5/13/2015	Bronx	1430	WEBSTER AVENUE	1	0	A pedestrian was struck by a piece of rigid foam insulation that fell from the building. The pedestrian did not receive medical attention and left the site. DOB issued a violation and stop work order.	ECB Violation	#35131990X/35131993L	051315CSSU202-05	Alt 3	220049775	Worker Fall	NYC HOUSING AUTHORITY	Metropolitan Enterprises
5/13/2015	Manhattan	1110	PARK AVENUE	0	1	Four pedestrians were injured when a job site fence fell. DOB issued a violation and stop work order.	ECB Violation	#351180632/35118064K	51315CNCM01 & 02	ALTERATION TYPE 3	121890703-01-EQ-OT	Scaffold/Shed/Fence/Shoring/Installation	1411 IC-3IC PROPERTY LLC	ALL-SAFE LLC
5/14/2015	Brooklyn	342	LAFAYETTE AVENUE	0	1	A resident was struck by some plaster during renovation. The resident was taken to the hospital by ambulance.	ECB Violation	#5126887L/35126887L	051415CERDM02 & 03	ALTERATION TYPE 2	320813679-01-EV-OT	Material Fall	PARK MONROE II REHAB HOUSING D	MDG DESIGN & CONSTR LLC
5/14/2015	Manhattan	130	EAST 82 STREET	0	1	The Site Safety Manager reported to DOB that a worker injured his elbow while opening a gang box. The worker was taken to the hospital by a company worker.	No Dispatch					Other Construction Related Incidents	134 EAST 82 LLC	
5/15/2015	Brooklyn	285	JAY STREET	0	1	The Site Safety Manager reported to DOB that a steel worker fell down the stairs, approximately 3 steps, and complained of back pain. EMS was called.	No Dispatch					Worker Fall	DORMITORY AUTHORITY OF THE STA	
5/15/2015	Queens	2745	JACKSON AVENUE	0	1	A worker fell from a ladder when he lost control of the drill he was using to drill anchor bolts for rebar. The worker was taken to the hospital by ambulance with scrapes and bruises.	ECB Violation					Worker Fall	27-45 JACKSON AVENUE LLC	
5/18/2015	Manhattan	68	CHARLTON STREET	0	1	A worker suffered from smoke inhalation when sparks ignited waterproofing on the foundation wall. There was a fireguard with extinguishers present. The fire continued to ignite and FDNY was called to extinguish the fire. The worker was taken to the hospital by ambulance.	ECB Violation	#35130938X				Excavation/Soil Work	68 & 74 CHARLTON STREET COMAPN	
5/19/2015	Manhattan	507	WEST 28 STREET	0	1	A worker fell from the first floor to the basement. The worker was conscious when taken to the hospital by ambulance. DOB issued violations.	ECB Violation					Worker Fall	KADIMA TENTH AVENUE SPE LLC	
5/19/2015	Manhattan	159-48	HARLEM RIVER DRIVE	0	1	A worker fell through a corrugated metal decking while dismantling a sidewalk shed. The worker was taken to the hospital with minor injuries and was released the next day. DOB issued a violation.	ECB Violation	#35132105Z	051915CSSU202	Alt 3	140270276	Worker Fall	N Y C H A F H A	Crew Contracting of NJ
5/19/2015	Brooklyn	363	BOND STREET	0	1	The Site Safety Manager reported to DOB that a worker cut his finger off while pulling rebar. EMS was called. Two workers were injured when the steel structure being erected collapsed. The injured workers were transported to the hospital in unknown condition. DOB issued a violation and stop work order.	No Dispatch					Other Construction Related Incidents	LSQ 363 BOND STREET LLC	
5/19/2015	Bronx	530	ZEREGA AVENUE	0	2	A construction worker was struck by falling bicycle style guard rails that fell when the construction fence gate was opened inward, knocking the guardrails into the excavation. The worker extracted himself from the excavation and was taken to the hospital by ambulance. DOB issued violations.	ECB Violation	#35127028H	051915CNEWB01	New Building	220352892	Material Fall	THE CITY OF NEW YORK	HMC Construction
5/20/2015	Brooklyn	535	CARLTON AVENUE	0	1	FDNY reported that a worker tripped and fell off a sidewalk shed. The worker was taken to the hospital with minor injuries. No workers were on site when DOB arrived. DOB issued a violation.	ECB Violation	#35130655P				Material Fall	ATLANTIC YARDS NOMINEE SUB A L	
5/21/2015	Brooklyn	409	FULTON STREET	0	1	The Site Safety Manager reported to DOB that a worker was injured while unloading steel panels from a truck. The worker went to an urgent care facility for stitches.	No Dispatch					Other Construction Related Incidents	TRUSTEES OF COLUMBIA UNIVERST	
5/26/2015	Queens	39-07	57 STREET	0	1	The Site Safety Manager reported to DOB that a plumber sustained burns while soldering pipe. The worker was taken to the hospital by the Fireman.	No Action Necessary					Other Construction Related Incidents	NEW YORK CITY SCHOOL CONSTRUCT	
5/27/2015	Queens	23-01	42 ROAD	0	1	A Site Safety Manager reported to DOB that a laborer stepped on a nail and went to a private medical facility for a tetanus shot. A Site Safety Manager reported to DOB that a laborer stepped on a nail and went to a private medical facility for a tetanus shot.	No Dispatch					Other Construction Related Incidents	QPS 23-10 DEVELOPMENT LLC	
5/28/2015	Manhattan	110	WEST 96 STREET	0	1	A worker fell from the top deck of a tall high-sidewalk shed through the fire escape opening. The worker was taken to the hospital.	No Action Necessary	NA	NA	Alt 2	121142708	Worker Fall	TOV EQUITIES	Vlad Restoration
5/28/2015	Manhattan	252	East 57 street	0	1	A worker complained of dizziness after being struck on top of his helmet. The site medical tech recommended the worker go to the hospital for further treatment. The worker's partner did not see the incident and DOB observed no evidence of any fallen material. No DOB action was necessary.	No Action Necessary					Worker Fall	NEW YORK CITY EDUCATIONAL CONS	

Monthly Accident Details: January - June, 2015

Incident Date	Borough	Address Number	Street	Fatalities	Injuries	EOC Final Description	DOB Action	ECB Violation Numbers	DOB Violation Numbers	Permit	Permit No	Incident Type	Owner's Name	Contractor Name
5/28/2015	Manhattan	585	8 AVENUE	0	1	A pedestrian slipped on a fast ramp and was taken to the hospital by ambulance. DOB issued a violation. The Site Safety Manager reported to DOB that a worker injured his foot while moving a door. The worker went a medical facility for X-rays.	ECB Violation	#35130044P				Other Construction Related Incidents	IMDN HOLDING LLC	
5/28/2015	Manhattan	605	WEST 129 STREET	0	1		No Dispatch					Other Construction Related Incidents	TRUSTEES OF COLUMBIA UNIVERST	
5/29/2015	Queens	39-07	57 STREET	0	1	An electrician was struck on his hand hat by a pipe that fell. The pipe was leaning against a wall and fell when another worker kicked the plank on which the pipe rested causing it to fall. The injured worker was taken to the hospital with no visible injury. DOB issued a violation.	ECB Violation	#3513105R				Material Fall	NEW YORK CITY SCHOOL CONSTRUCT	
5/29/2015	Manhattan	300	CHERRY STREET	0	1	During asbestos removal, a worker was struck by a fork lift and sustained a broken leg.	Referred to another Uni/City Agency					Mechanical Construction Equipment	NYC CITY HSG AUTHORITY	
5/00/2015	Brooklyn	433	LAFAYETTE AVENUE	0	1	During demolition of parapet on steel, a brick fell striking the hard hat of a worker working below. The injured worker was taken to the hospital. DOB issued violations and stop work order.						Material Fall	NYC HOUSING AUTHORITY	
5/31/2015	Manhattan	261	MADISON AVENUE	0	7	Seven people were injured when a crane dropped the refrigerator absorbing unit it was lifting.	DOB Violation		053115CNE01L1C 2L2C	ALTERATION TYPE 2 CN015315	12233429-01-EW-OT	Mechanical Construction Equipment	260-261 MADISON AVE LLC	ASRR CONSTRUCTION LLC
6/1/2015	Manhattan	860	WASHINGTON STREET	0	1	The Site Safety Manager reported to DOB that a worker was caught between a cart and rail as he was help to load a hoist. The injured worker was taken to the hospital.	No Dispatch			New Building	121326483	Other Construction Related Incidents	860 WASHINGTON STREET LLC	JAN GRIMSAND
6/2/2015	Manhattan	150	CHARLES STREET	0	1	The Site Safety Manager reported to DOB that a carpenter's arm was cut and he went for medical treatment and returned to work.	No Dispatch					Other Construction Related Incidents	150 CHARLES STREET HOLDINGS, L	
6/2/2015	Manhattan	41	EAST 22 STREET	0	1	A worker was struck by a bolt during installation of a tower crane. The worker was taken to urgent care by cab.	ECB Violation	#35116665R		CN	CN875/15	Mechanical Construction Equipment	45 EAST 22ND STREET PROPERTY L	
6/3/2015	Manhattan	133	GREENWICH STREET	0	1	The Site Safety Manager reported to DOB that a Port Authority LT reported that a construction worker claimed to have been struck by a rail that fell from the site. The worker went to the hospital for a tetanus shot.	ECB Violation	#35130275M/35130276Y				Material Fall	133 GREENWICH STREET ASSOCIATE	
6/4/2015	Brooklyn	181	FRONT STREET	0	1	A steel beam fell on a worker's foot when workers used an excavator machine with shackles halfway out to create a makeshift lift for the steel beam. The injured worker was taken to the hospital. DOB issued a violation and stop work order.	ECB Violation					Mechanical Construction Equipment	177 FRONT PROPERTY OWNER, L.L.	
6/4/2015	Brooklyn	285	JAY STREET	0	1	The Site Safety Manager reported to DOB that a worker injured his leg while removing steel and EMS was called. The Site Safety Manager reported to DOB that a glass panel fell on a workers foot during unboding of the panel. The worker was sent to the hospital for observation. No DOB action was necessary.	No Dispatch					Other Construction Related Incidents	DORMITORY AUTHORITY OF THE STA	
6/4/2015	Manhattan	135	WEST 52 STREET	0	1	The Site Safety Manager reported to DOB that while taking down a scaffold panel, it bounced off the floor and struck a worker's foot. The worker was taken to First Aid.	No Dispatch					Other Construction Related Incidents	135 WEST 52ND STREET OWNER LLC	
6/4/2015	Manhattan	220	CENTRAL PARK SOUTH	0	1	The Site Safety Manager reported to DOB that a worker's hand was pinched when the excavation cage they were loading was put down. The worker went to a clinic for a tetanus shot.	No Dispatch					Other Construction Related Incidents	VNO 225 WEST 58TH STREET LLC	
6/4/2015	Queens	28-30	JACKSON AVENUE	0	1	A pedestrian was injured when a section of chain link fence fell. The pedestrian was taken to the hospital with a head injury. DOB issued a violation.	No Dispatch					Other Construction Related Incidents	LIC DEVELOPMENT OWNER, L.P.	
6/7/2015	Brooklyn	505	GATES AVENUE	0	1	The Site Safety Manager reported to DOB that a worker was stripping pile and was hit in the eye area. The worker was sent for medical treatment.	ECB Violation	#35126892X	060715CERDM01			Scaffold/Shed/Fence/Shoring/Installation	NYC HOUSING AUTHORITY	
6/8/2015	Manhattan	70	CHARLTON STREET	0	1	The Site Safety Manager reported to DOB that a carpenter cut his finger while moving bathroom stalls. The carpenter was taken to the emergency room for stitches.	No Dispatch					Other Construction Related Incidents	NEW YORK UNIVERSITY	
6/8/2015	Manhattan	605	WEST 129 STREET	0	1	The Site Safety Manager reported to DOB that an electrician slipped while pushing a cart and pulled his left shoulder muscle. The electrician went on his own for X-rays.	No Dispatch					Other Construction Related Incidents	TRUSTEES OF COLUMBIA UNIVERST	
6/10/2015	Brooklyn	285	JAY STREET	0	1	The Site Safety Manager reported to DOB that a worker's leg was pinched while moving a cart onto a hoist. EMS was called.	No Dispatch					Other Construction Related Incidents	DORMITORY AUTHORITY OF THE STA	
6/10/2015	Brooklyn	626	FLATBUSH AVENUE	0	1	The Site Safety Manager reported that a pedestrian was struck on the hand by a brick that fell from approximately the twentieth floor. The pedestrian was taken to the hospital by EMS with minor injury.	ECB Violation	#35109095Z/35109096K				Material Fall	HUJSDON CBD FLATBUSH LLC	
6/12/2015	Manhattan	220	CENTRAL PARK SOUTH	0	1	The Site Safety Manager reported to DOB that a carpenter was struck on the arm by a piece of form work sustaining a slight laceration. The carpenter was sent for medical attention.	No Dispatch					Other Construction Related Incidents	VNO 225 WEST 58TH STREET LLC	
6/13/2015	Manhattan	701	7 AVENUE	0	1	The Site Safety Manager reported to DOB that a pedestrian tripped and fell in front of site. EMS was called.	No Dispatch					Other Construction Related Incidents	701 SEVENTH PROPERTY OWNER LLC	
6/13/2015	Manhattan	855	6 AVENUE	0	1	A worker was injured when sheetrock fell off an A-frame being used to move the sheetrock. The worker was taken to the hospital by ambulance in unknown condition. No DOB action was necessary.	No Action Necessary					Other Construction Related Incidents	855 MRU LLC	
6/15/2015	Manhattan	605	WEST 129 STREET	0	1	The Site Safety Manager reported a worker cut his arm on a piece of metal stud and went to the hospital for stitches.	No Dispatch					Other Construction Related Incidents	TRUSTEES OF COLUMBIA UNIVERST	
6/16/2015	Manhattan	1	7 AVENUE	0	1	A worker fell down to the next level when he tripped on a plank being used as a mudflat under a scaffold and was extending approximately four feet beyond the scaffold. The injured worker was taken to the hospital. DOB issued a violation and stop work order.	ECB Violation	#35131056R				Worker Fall	WEST VILLAGE HOLDINGS LLC	
6/16/2015	Manhattan	475	PARK AVENUE SOUTH	0	1	An engineer sustained a laceration and back pain when she fell when the extension ladder she was using to access a scaffold, kicked out. The engineer was taken to the hospital by ambulance. No DOB action was necessary.	No Action Necessary					Worker Fall	475 PARK AVENUE SOUTH	
6/16/2015	Manhattan	100	EAST END AVENUE	0	1	The Site Safety Manager reported to DOB that a laborer dropped a door on his foot and was transported to the hospital.	No Dispatch					Other Construction Related Incidents	THE CHAPIN SCHOOL LTD	
6/19/2015	Manhattan	303	EAST 51 STREET	0	1	A worker fell approximately ten to twelve feet when the plank he was using broke. The plank was nailed at one end and extended off a scaffold and used to access the work. The injured worker was taken to the hospital. DOB issued a violation and stop work order.	ECB Violation	#35129956J				Worker Fall	51ST STREET MAN LOT OWNER LLC	



Monthly Accident Details: January - June, 2015

Incident Date	Borough	Address Number	Street	Fatalities	Injuries	ECF Final Description	DOB Action	ECB Violation Numbers	DOB Violation Numbers	Permit	Permit No	Incident Type	Owner's Name	Contractor Name
6/19/2015	Manhattan	310	WEST 40 STREET	0	1	A worker fell through a hole after removing the protection. The worker was taken to the hospital by ambulance in unknown condition. DOB issued violations and stop work order.	ECB Violation	#351031069M/35131061L/26131060J				Worker Fell	NOT ON FILE	
6/22/2015	Manhattan	444	10 AVENUE	0	1	The Site Safety Manager reported to DOB that a concrete worker scrapped his arm with a piece of concrete while cleaning the stairs and rebared patches.	No Access					Other Construction Related Incidents	CARE REALTY CORP	
6/24/2015	Bronx	1191	BOSTON ROAD	0	1	The Site Safety M reported to DOB that a cement mixer driver fell the chute and sustained a head injury.	No Dispatch					Worker Fell	BOSTON ROAD II HOUSING DEVELOP	
6/24/2015	Brooklyn	370	JAY STREET	0	1	The Site Safety Manager reported to DOB that a worker fell approximately three feet from a six foot A frame ladder while doing duct work. EMS was called.	No Dispatch			OT	321130478	Worker Fell	NOT ON FILE	GRACIANO CORP
6/24/2015	Manhattan	150	CHARLES STREET	0	1	The Site Safety Manager reported to DOB that an electrician working in the cellar fell from an eight foot ladder and sustained arm and head injuries.	No Dispatch					Worker Fell	150 CHARLES STREET HOLDINGS, L	
6/25/2015	Brooklyn	365	BOND STREET	0	1	The Fire Safety reported to DOB that a worker fell one foot off a whaler and EMS was called.	No Dispatch					Worker Fell	LSG 365 BOND STREET LLC	
6/26/2015	Manhattan	221	WEST 29 STREET	0	1	A worker was struck by drilling equipment while four workers were drilling caissons. The injured worker was conscious when taken to the hospital by ambulance. DOB issued a violation and stop work order.	ECB Violation	#35129959P				Mechanical Construction Equipment	29 PARK LLC	
6/28/2015	Manhattan	50	WEST STREET	0	1	The Site Safety Manager reported to DOB that a worker perched his forearm with a nail while propping forms. The worker went to the doctor on his own.	No Dispatch					Other Construction Related Incidents	50 WEST DEVELOPMENT LLC	
6/30/2015	Manhattan	203	EAST 92 STREET	0	1	A worker sustained an electrical shock when the worker struck an electrical line while chipping concrete at the ground level. The worker was taken to the hospital.	ECB Violation	#35146138Y				Other Construction Related Incidents	CARNEGIE PARK LAND HOLDING, LL	
6/30/2015	Manhattan	305	WEST 46 STREET	0	1	The Site Safety Manager reported to DOB that a worker sustained a laceration to his hand when he the glass cutter slipped while he was lifting a glass door. The worker was sent to the hospital for stitches.	No Dispatch					Other Construction Related Incidents	741 EIGHTH AVENUE OWNERS, LLC	
<b>Grand Total</b>				<b>4</b>	<b>196</b>									