



DEPARTMENT OF BUILDINGS
EXECUTIVE OFFICES
60 HUDSON STREET, NEW YORK, N.Y. 10013
RUDOLPH J. RINALDI, COMMISSIONER

RALPH S. HERMAN, R.A.
Assistant Commissioner
Technical Review & Compliance
(212) 312-8324

TO: BOROUGH SUPERINTENDENTS

FROM: Ralph S. Herman, R.A.
Assistant Commissioner

DATE: October 1, 1990

SUBJECT: FIRESTOPPING

Please remind your Plan Examiners of the following:

1. Firestopping, like all items of Controlled Inspection, shall be listed as subject to Controlled Inspection on the first drawing of the Application.
2. A firestopping requirement may result from the work of Mechanical Trades. Such work might not be shown on the Architectural Plans. If such work is anticipated but shown only on the Mechanical Plans, firestopping shall be listed as a Controlled Inspection item on the Architectural Plans.

RSE:rmr

cc: Architecture & Engineering Organizations