



DEPARTMENT OF BUILDINGS  
EXECUTIVE OFFICES  
60 HUDSON STREET, NEW YORK, N.Y. 10013  
RUDOLPH J. RINALDI, COMMISSIONER  
312-8100

April 26, 1990

Mr. Joseph John Besada  
Sales Manager  
Skyhook, Inc.  
20 North Avenue  
Larchmont, New York 10538

Re: BEK Mobile Work Platform

Dear Mr. Besada:

After our last telephone conversation, we held an in-house meeting to resolve the issues of the above reference subject matter.

Since your equipment is attached to the building walls, you need a Board of Standards and Appeals approval for such equipment. Then your applicant (professional engineer or registered architect) files an application for the use of said equipment. The application shall include the plan showing how the equipment is attached to the building walls and calculations that equipment is capable of actual loading, ground condition supporting this equipment and strength of wall connections. The applicant must file a control inspection report verifying above requirements.

The application shall be filed in the borough offices of the Department of Buildings where the equipment is being used.

Very truly yours,

  
Nalin T. Patel, P.E.  
Director of Local Law Reveiw

NTP:rmr

cc: Commissioner R. J. Rinaldi  
First Assistant Commissioner, G. C. Sakona, P.E.  
Assistant Commissioner, J. Grill, P.E.—Cranes & Derricks  
Borough Superintendents  
Administrative Elevator Inspector, A. Watson