



DEPARTMENT OF BUILDINGS
EXECUTIVE OFFICES
60 HUDSON STREET, NEW YORK, N.Y. 10013
RUDOLPH J. RINALDI, Commissioner
312-8100

TECHNICAL
POLICY AND PROCEDURE NOTICE #5/93

TO: Distribution
FROM: Richard C. Visconti, A.I.A. *Richard Visconti*
Acting Deputy Commissioner
DATE: May 19, 1993
SUBJECT: Use of Non-Coded Manual Fire Alarm Pull
Stations in a Coded Fire Alarm System.

Effective: Immediately

Purpose: To interpret the Administrative Code regarding the use of Non-Coded Manual Fire Alarm Pull Stations in a Coded Fire Alarm System.

Specifics: Section 7 of Reference Standards RS 17-3, RS 17-3A and RS 17-3B of the Administrative Code specifies two types of Fire Alarm Sending Stations, Coded and Non-Coded Manual Pull Stations.

The terms Coded or Non-Coded, as it relates to the type of Manual Pull Stations, do not necessarily dictate the classification of the Fire Alarm System in which it can be used.

Therefore, Non-Coded Manual Pull Stations may be used in all types of Coded Fire Alarm Systems when a BSA approved or MEA accepted module is used in conjunction with these Manual Pull Stations, and they will generate the required coding at the panel provided the BSA resolution or MEA acceptance for the Manual Pull Stations do not restrict its use to a specific class of Fire Alarm System.