



DEPARTMENT OF BUILDINGS
EXECUTIVE OFFICES
60 HUDSON STREET, NEW YORK, N.Y. 10013
RUDOLPH J. RINALDI, Commissioner

GEORGE C. SAKONA, P.E.
Deputy Commissioner
Technical Affairs
(212) 312-8120

September 30, 1991

Mr. David Mozur
Cosentini Associates
Consulting Engineers
Two Pennsylvania Plaza
New York, New York 10121

Re: Smoke Detectors in Patient Bedrooms
of Fully Sprinklered Hospitals


Dear Mr. Mozur:

This is in response to your letter dated September 26, 1991 regarding the requirements of sprinklers and smoke detectors in hospitals.

The intent of the law was to have sprinklers in patient rooms if required by other provisions of the Building Code. When sprinklers are not required in patient rooms, the intent of the law was to provide either sprinkler or smoke detectors.

Therefore, sprinklers in patient rooms in a fully sprinklered hospital building will be acceptable without smoke detectors.

Very truly yours,


George C. Sakona, P.E.
Deputy Commissioner

GCS:NTP:rmr

cc: Commissioner R. J. Rinaldi, R.A.
Assistant Commissioner R. C. Visconti, A.I.A.
Executive Engineer I. Polsky, P.E. ✓
Borough Commissioners/Superintendents
Chief Robert Manson, Bureau of Fire Prevention