



DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES  
60 HUDSON STREET, NEW YORK, NY 10013

CHARLES M. SMITH, Jr., R.A., Commissioner  
312-8100

MEMORANDUM

TO: GEORGE SAKONA, P.E.  
BOROUGH SUPERINTENDENT

FROM: GEORGE E. BERGER, P.E. *geb*  
ACTING DEPUTY COMMISSIONER

DATE: DECEMBER 20, 1989

SUBJECT: TYPE B GAS VENTS FOR MULTI-STORY INSTALLATIONS

---

The applicant, Lawrence Stamp, installed ceiling mounted gas fired space heaters for multi-level storage warehouse located at 444 East 10th Street under B.N. #221/89.

On October 27, 1989 an inspection was made to test gas connections. The gas test was approved with the objection stating that flue pipe connected to common flue is not allowed.

The applicant has requested this office to reconsider the above objection which was denied by the borough superintendent.

Section 27-884 allows the gas fired equipment to vent through multi-story type B gas vents. MEA 5-70-E Vol. II gas fired equipment are installed with Board of Standards and Appeals approved gas vent and flue pipe (Cal. #538-48-SM).

Therefore, the said objection is hereby reconsidered provided above installation meets the stated requirements.