

THE CITY OF NEW YORK
HOUSING AND DEVELOPMENT ADMINISTRATION
DEPARTMENT OF BUILDINGS

DEPARTMENTAL MEMORANDUM

DATE: February 19, 1971

TO: Borough Superintendents
FROM: Thomas V. Burke, Director of Operations
SUBJECT: Plenum Walls

This is to confirm my previously issued verbal instructions on the above subject. Walls, partitions and other enclosures of plenum chambers or shafts, subject to air pressure differentials, shall be designed to withstand the maximum pressure that may be developed under any conditions.

Examiners are to require that such maximum pressures shall be indicated on the plans and shall check for structural compliance.


Thomas V. Burke
Director of Operations

cc: Com. J. Ferro
Dep. Com. J. Stein
Asst. Com. F. Padavan
Executive Staff