

THE CITY OF NEW YORK  
HOUSING AND DEVELOPMENT ADMINISTRATION  
DEPARTMENT OF BUILDINGS

DEPARTMENTAL MEMORANDUM

DATE: December 2, 1976


TO: Charles J. Poidomani, Dir. of Operations, OCE

FROM: Director of Operations Irving E. Minkin

SUBJECT: Securing Fire Escape Treads

In response to your memorandum of September 29, 1976, regarding a modification of Rule 4.20.1 in regard to the use of 3/8" bolts, you are advised that 5/16" bolts may be used to secure the treads to the supporting angles, in accordance with Rule 4.24, provided the threaded portion of the bolts extends beyond the metals joined.

This would not conflict with the Building Code.



Irving E. Minkin  
Director of Operations

IEM/df

CC: Exec. Staff  
Boro. Supts.

1247