



DEPARTMENT OF BUILDINGS

EXECUTIVE OFFICES
60 HUDSON STREET, NEW YORK, NY 10013

CHARLES M. SMITH, Jr., R.A. Commissioner

April 28, 1989

GEORGE E. BERGER, P.E.
Assistant Commissioner
Building Construction

Mr. Walter Gorman, P.E., P.C.
115-14 Beach Channel Drive
Rockaway Park, New York 11694

RE: 1 Little Street
Brooklyn

Dear Mr. Gorman:

Your request in a letter, dated February 28, 1989 for variance to allow use of exposed fluoropolymer wiring in lieu of THHN in rigid conduit for the installation of smoke detection system in above referenced building is approved with the following requirements:

1. Fluoropolymer (teflon) wiring without conduit in floor spaces shall be above the hung ceiling.
2. All vertical risers and wiring in other exposed areas shall be in rigid conduits.
3. Fluoropolymer wiring shall be Board of Standards and Appeals approved and shall be used for the system operating under 50 volts.

Very truly yours,

George E. Berger, P.E.
Assistant Commissioner

GEB:NTP:lg

cc: Shirley Klein, R.A., Borough Superintendent
Chief Joseph DeMeo, Fire Department
Henry Gittlitz, Fire Department
Deputy Commissioner C. Dennis, P.E.
Executive Engineer, I. Polsky, P.E.
Borough Superintendents