

THE CITY OF NEW YORK
HOUSING AND DEVELOPMENT ADMINISTRATION
DEPARTMENT OF BUILDINGS

DEPARTMENTAL MEMORANDUM

DATE: January 24, 1972

TO: Borough Superintendents and Executive Staff
FROM: Philip E. Olin, P.E., Ass't. Directive of Operations
SUBJECT: EGRESS - DOOR HARDWARE - C26-604.4(J)

The Statement on this Reconsideration
RE: Door Hardware [C26-604.4(J)] Shall be Considered a Precedent
Based upon: Departmental Memorandum dated January 17, 1972 -

"The doors leading directly into stairway enclosures that serve as entrance doors to dwelling units as well as doors to the enclosed stairways are required to conform with Section C26-604.4 (j) (2). In such instances, the provisions of the code relating to security requirements for doors in dwelling units will supersede the provisions of Section C26-604.4 (j) (1). This shall be considered to be a precedent and applicable to all similar conditions."

Signed
Joseph Stein, P.E.
Commissioner

643