

1 RCNY §38-01

CHAPTER 38 VENTILATION

§38-01 Ventilation of Garage Spaces Below Grade.

- (a) Wherever the floor of a garage designed for the live storage of five (5) or more motor vehicles is more than two (2) feet below curb, ventilation shall be provided as required by the provisions of subdivision a of §C26-267.0 of the Administrative Code.[sic]
- (b) Air exhaust ducts shall terminate above the roof of the garage or the roof of the building or shall terminate at least ten (10) feet above the curb in an exterior wall adjoining a legal street, yard or court. No air exhaust duct shall terminate within fifteen (15) feet of a window in another building, nor within fifteen (15) feet of a window in the residence portion of the same building.
- (c) The ventilating system shall comply with Reference Standard 13.