

## 1 RCNY §40-36

### CHAPTER 40 INSTALLATION AND MAINTENANCE OF GAS-FUELED WATER AND SPACE HEATERS IN ALL PORTIONS OF DWELLINGS USED OR OCCUPIED FOR LIVING PURPOSES

#### Subchapter

- A *Scope*
- B *Departmental Procedure*
- C *Where Heaters May be Used*
- D *Installation of Gas-Fueled Heaters*

#### Subchapter D *Installation of Gas-Fueled Heaters*

##### **§40-36 Gas Piping.**

(a) The sizes of gas piping shall be such as to give an adequate volumetric flow of gas to all appliances. The minimum diameter of gas piping shall be three-quarters of an inch (3/4") except that a branch supplying only one appliance may be one-half inch (1/2") diameter.

(b) Each gas-fueled space and water heater shall be rigidly connected to the gas piping supplying gas to the apartment.