



January 15, 2021

ADDENDUM #5 to PIN 072202003CPD

George R. Vierno Center (GRVC) Methane Mitigation
and Detection System Upgrade

Dear Prospective Bidder:

Pursuant to 3-02(i)(2) of the Procurement Policy Board (PPB) Rules, the Department of Correction (Department) is issuing Addendum #5 to the solicitation for the services referenced above.

REVISED BID DUE DATE

Please be advised that the Bid Opening Date for the above referenced procurement has been extended from:

- Wednesday, January 20, 2021 to **Tuesday, January 26, 2021**
- The time **(12:00PM)** is unchanged

NO MORE CLARIFICATIONS ARE ACCEPTED.

CLARIFICTION TO ADDENDUM #4

Q.1 Add/Alt #1 (added with Addendum #4), shows the use of a fiber optic converter panel, however, does not tell us how many fibers will need to be landed on this panel or where this fiber optic network is. Please advise on the quantity of fiber as well as the connection type required.

Response: Provide 6 single mode 9-micron fibers for the project with standard connector (SC). The fiber optic network is within the facility, and for bid purposes, the contractor shall include extending the fiber optic cable for 100 ft. for connection to the Rikers fiber network.

Please sign below in acknowledgment of this addendum. ***Submit this addendum with your bid.***

Agency Chief Contracting Officer

I acknowledge receipt of this addendum.

Proposer/Company Name (Print)

Authorized Representative (Print Name)

Authorized Representative (Signature)

Date