



NEW YORK CITY DEPARTMENT OF CORRECTION  
Cynthia Brann, Commissioner  
Ava B. Rice, Assistant Commissioner  
Contracts and Procurement  
Agency Chief Contracting Officer  
75-20 Astoria Boulevard, Suite 160  
East Elmhurst, NY 11370  
Office: 718 546-0690  
Fax: 718 278-6205

January 19, 2021

**ADDENDUM # 6 to PIN 072202007CPD**  
**RMSC METHANE DETECTION SYSTEM**

Dear Prospective Bidder:

Pursuant to §3-02(i) of the Procurement Policy Board (PPB) Rules, the Department of Correction (DOC) is issuing Addendum # 6 to the solicitation for the services referenced above.

**Please be advised of the following clarifications:**

- 1. Add/Alt #1 (added with Addendum #4) shows the use of a fiber optic converter panel. However, it does not tell how many fibers will need to be landed on this panel or where this fiber optic network is. Please advise on the quantity of fiber, as well as the connection type required.**

*Response: Provide 6 single mode 9 micron fibers for the project with standard connector (SC). The fiber optic network is within the facility, and for bid purposes, the contractor shall include extending the fiber optic cable for 100 ft. for connection to the Rikers fiber network.*

**BID DUE DATE**

- PLEASE NOTE: The BID DUE DATE has been extended to Friday, January 29, 2021, at 11:00 AM.**
- Please contact the Contract Manager, Alvis-Mae Brade-John, at [Alvis-Mae.Brade-John@doc.nyc.gov](mailto:Alvis-Mae.Brade-John@doc.nyc.gov) by 3:00 PM January 28, 2021, if you would like to attend the bid opening, which will be held by video conference.**

Please sign below in acknowledgment of this addendum and submit this addendum with your bid. Failure to do this may result in your bid being considered non-responsive.

All other aspects and requirements of the bid remain unchanged.

---

Agency Chief Contracting Officer

**I acknowledge receipt of this addendum.**

---

**Bidder/Company Name (Print)**

---

**Authorized Representative (Print Name)**

---

**Authorized Representative (Signature)**

**Date**