

## CHAPTER 8 COOLING TOWERS

§8-01 **Scope and applicability.**

§8-02 **Definitions.**

§8-03 **Maintenance program and plan.**

§8-04 **Process control measures.**

§8-05 **Water treatment.**

§8-06 **System shutdown and start-up; commissioning and decommissioning cooling towers.**

§8-07 **Records.**

§8-08 **Modification.**

§8-09 **Penalties.**

§8-01 **Scope and applicability.** This Chapter applies to owners of New York City buildings or other premises in the City that are equipped with a cooling tower system.

§8-02 **Definitions.** When used in this Chapter, the following terms mean:

“ANSI/ASHRAE 188-2015” means sections 5, 6 and 7.2 of *ANSI/ASHRAE Standard 188-2015 Legionellosis: Risk Management for Building Water Systems*, a publication issued by the American National Standards Institute (ANSI)/American Society of Heating, Refrigeration and Air-Conditioning Engineers (ASHRAE), final approval date June 26, 2015, at pages 4-8.

“Bacteriological indicator” means a biological process control indicator that estimates microbial content in the circulating water of a cooling tower system, such as heterotrophic plate count (HPC) as measured in a water sample or by a dip slide.

“Biocidal indicator” means a direct or indirect measure of the effectiveness of biocide, consisting of free halogen residual concentration or oxidation reduction potential (ORP), as specified in the management program and plan.

“Building” means any structure used or intended for supporting or sheltering any use or occupancy. The term shall be construed as if followed by the phrase “structure, premises, lot or part thereof” unless otherwise indicated by the text.

“Cleaning” means physical, mechanical or other removal of biofilm, scale, debris, rust, other corrosion products, sludge, algae and other potential sources of contamination.

“Cooling tower” means a cooling tower, evaporative condenser or fluid cooler that is part of a recirculated water system incorporated into a building’s cooling, industrial process, refrigeration, or energy production system.

“Cooling tower system” means one or more cooling towers and all of the recirculating water system components, process instruments and appurtenances through which water flows or comes into contact with key parts consisting of biocide, anti-scaling and anti-corrosion chemical applicators, valves, pumps, the tower superstructure, condensers and heat exchangers and other related components. The cooling tower system may comprise multiple cooling towers that share some or all superstructure components.

“Corrective actions” mean disinfection, cleaning, flushing, and other activities to remedy biofilm growth, *Legionella* proliferation, or other system mechanical problems identified through monitoring, inspections, or other means as may be determined by the Department.

“Compliance inspection” means the inspection, testing and other activities that are required on a regular basis (at least every 90 days) in accordance with the maintenance program and plan and this Chapter, including the completion of a written or electronic checklist, and must be conducted and certified by a qualified person.

“Dead legs” mean lengths of pipe normally closed at one end or ending in a fitting within the cooling tower system that limits water circulation and is likely to result in stagnant water in the system.

“Department” means the New York City Department of Health and Mental Hygiene.

“Dip slide” means a method to test for microorganisms (such as HPC) consisting of a sterile culture medium affixed to a sterile slide, that is dipped directly into the liquid that is to be sampled.

“Disinfection” means using one or more of the biocides registered with the New York State Department of Environmental Conservation at a defined concentration, under specific conditions and for an established period that will kill or inactivate pathogenic microorganisms.

“Drift eliminator” means a system of baffles or cells that cause separation of entrained water designed to remove aerosols from cooling tower exhaust.

“Heterotrophic plate count” or “HPC” means a measure of the concentration of microorganisms that require an external source of organic carbon for growth including bacteria, yeasts and mold in water samples.

“Idling” means turning off or limiting water circulation within the cooling tower system but not draining the system water.

“Immediate” or “immediately” means within 24 hours when used in regards to (i) actions required to be taken under this Chapter, or (ii) incidents or results required to be reported under this Chapter, or (iii) records required to be made available to the Department under this Chapter.

“*Legionella*” means the genus of bacteria which is ubiquitous in aqueous environments, including the recirculated water of cooling tower systems that are not properly or regularly maintained. There are more than 50 different species of *Legionella*, all of which are potentially pathogenic.

“*Legionella* sample” means water or other sample to be examined for the presence of viable *Legionella* bacteria using semiselective culture media and procedures specific to the cultivation and detection of *Legionella* species, such as those outlined in International Organization for Standardization (ISO) Standards 11731-1:1998 and 11731-2:2004.

“Maintenance program and plan” or “plan” means a written set of measures describing monitoring, cleaning, disinfection and all other activities for the prevention and control of *Legionella* growth in a cooling tower system, that is in accordance with section 5, 6 and 7.2 of ANSI/ASHRAE 188-2015 and with the manufacturer’s instructions, and is developed by a qualified person.

“Makeup water” means water added to the cooling tower system on a regular basis to replace water lost by evaporation, drift or leakage and to maintain optimal system operation and process control.

“Management and maintenance team” means the individual or individuals designated by a building owner to be responsible for the continued effective and safe operation of a cooling tower system.

“Owner” means any person, agent, firm, partnership, corporation or other legal entity having a legal or equitable interest in, or control of the premises.

“Process control measures” mean actions that must be taken to evaluate internal functioning of the cooling tower system, including monitoring conductivity, pH, biological indicators and other parameters, and observing phenomenon such as scaling, corrosion and biofilm.

“Qualified person” means a New York State licensed and registered professional engineer; a certified industrial hygienist; a certified water technologist with training and experience developing management plans and performing inspections in accordance with current standard industry protocols including, but not limited to ANSI/ASHRAE 188-2015; or an environmental consultant who has at least two (2) years of operational experience in water management planning and operation.

“Responsible person” means a person employed or whose services are retained by an owner, who understands and is capable of performing the required daily water quality measurements, weekly system monitoring and operation and maintenance of a cooling tower system in accordance with the maintenance program and plan, and making recommendations for diagnosing anomalous conditions that require corrective actions, under the guidance of a qualified person. The responsible person should be capable of measuring water pH, temperature and disinfectant residual levels at proper locations/frequencies; checking biocide storage container levels; recording dates, amounts and times of biocide injection; and logging all other relevant data and comments.

“Risk management assessment” means a process for comprehensively identifying, describing and evaluating in detail all aspects of a cooling tower system that may potentially contribute to the growth and dissemination of *Legionella* bacteria.

“Routine monitoring” means evaluation and other activities that must be completed periodically in accordance with the maintenance program and plan and this Chapter.

“Stagnant water” means water that is confined, standing, experiencing a period of low flow or usage, and not being actively circulated through the cooling tower system.

“Standard methods” means accepted protocols for sampling, recording, laboratory testing, reporting and other procedures related to environmental and water quality sampling, including, but not limited to, those set forth in *Standard Methods for the Examination of Water and Wastewater* 22<sup>nd</sup> Edition, 2012, a publication issued jointly by the American Public Health Association, the American Water Works Association and the Water Environment Federation and the *Standards Microbiological Methods* (TC 147/SC4) published by the International Organization for Standardization, or successor editions.

“System shutdown” means shutting off or closing and draining the cooling tower system when cooling is no longer needed.

“System start-up” means commissioning a new system, or putting the cooling tower system into operation after system shutdown or idling.

“Water quality parameters” means temperature, pH, conductivity, biocidal indicator, bacteriological indicator and other chemical and physical indicators of system process control.

**§8-03 Maintenance program and plan.** For each cooling tower system the owner must have a maintenance program and plan prepared by a qualified person in accordance with sections 5, 6 and 7.2 of *ANSI/ASHRAE 188-2015*, the manufacturer’s instructions, and the requirements of this Chapter. The plan must be kept current and amended by a responsible or qualified person as needed to reflect any changes in the management and maintenance team, system design, operation or system control requirements for the cooling tower system. The plan must be kept in the building where a cooling tower or cooling tower system is located, or in an adjacent building or structure on the same campus, complex, lot, mall or on-site central engineering division, and must be made available to the Department for inspection upon and at the time of a request. At a minimum, the plan must include and describe:

- (a) *Management and maintenance team.* Identification, including names and contact information (mail and email addresses and telephone numbers) and description of the function of each person on the cooling tower system management and maintenance team, including:
  - (1) The owner of the building where each cooling tower system is located and any manager or other person designated by the owner as responsible for compliance with the requirements of Administrative Code §17-194.1 and this Chapter.
  - (2) Any person designated by the owner as a responsible person, as defined in §8-02 of this Chapter.
  - (3) Every consultant, service company and qualified person who cleans, disinfects, delivers chemicals or services the cooling tower system.
- (b) *Cooling tower system.* Identification, specifications and description of each cooling tower system and all components located at a specific address, including:
  - (1) The number of cooling towers in the cooling tower system.
  - (2) The location of each cooling tower in relation to the building and the building address, block and lot number.
  - (3) The dimensions and characteristics of the cooling tower system including total recirculating water volume, cooling tower tonnage, biocide delivery method, flow rate and other key characteristics.
  - (4) The purpose of the cooling tower system and seasonal or year-round operation including start and end date, if applicable. For systems with multiple cooling towers, conditional operation, such as cycling or scaling related to cooling demand, must also be noted.
  - (5) The New York City Department of Buildings registration number for each cooling tower.
  - (6) The cooling tower manufacturer, model number and serial number, if applicable.

- (7) A flow diagram or schematic of the cooling tower system, identifying all of the principal components and appurtenances of the cooling tower system including makeup water and waste stream plumbing locations.
- (c) *Risk management assessment.* The assessment must identify risk factors for *Legionella* proliferation and specify risk management procedures for all or parts of each cooling tower system, and anticipated conditions including:
- (1) Any dead legs or stagnant water in the recirculation system.
  - (2) Operating configurations and conditions that may occur after periods of extended inactivity lasting more than three (3) days, including idling or low circulation while not being fully drained.
  - (3) System parts that require continual operation throughout the year making regular, periodic offline cleaning and disinfection difficult.
  - (4) Any components that may add additional risk factors for organic material buildup and microbial growth such as strainers and out-of-use filters.
  - (5) Sources of elevated organic contamination, including, but not limited to windblown debris, bird waste and plant material.
  - (6) Design configurations that present risk of direct sun exposure on basin, deck or fill.
  - (7) Ventilation intakes or other routes for human exposure to cooling tower aerosols.
  - (8) System components adversely affecting water quality management procedures.
  - (9) Other risk or limiting factors or constraints in the cooling tower system's design and functioning.
- (d) *Cooling tower operation*
- (1) Control measures, corrective actions, documentation, including a written checklist for routine monitoring, and reporting that comply with sections 8-04 through 8-08 of this Chapter and any routine maintenance activities recommended by the manufacturer's instructions, including performance measures, which may sufficiently demonstrate adequate implementation of the operation requirements described in the maintenance program and plan. Where there is a conflict between the requirements of this Chapter, Part 4 of the State Sanitary Code, section 17-194.1 of the Administrative Code, and the manufacturer's instructions, the maintenance program and plan must reflect the most stringent requirement.
  - (2) Specific, detailed seasonal and temporary shutdown and start-up procedures.
  - (3) Notification and communication strategies among management and maintenance team members regarding the required corrective actions in response to process control activities, monitoring, sampling results and other actions taken to maintain the cooling tower system.

**§8-04 Process control measures.**

- (a) *Routine system monitoring.* An owner must designate a responsible person as defined in §8-02 of this Chapter to monitor each cooling tower system at least weekly while such system is in use.
- (1) The responsible person must enter on a written or electronic checklist provided and maintained by the owner all visual observations of the cooling tower system and associated equipment.
  - (2) The responsible person must possess the skills and have the knowledge necessary to be able to monitor the system under the guidance of a qualified person, in accordance with the management program and plan.
  - (3) All wetted surfaces visible during cooling tower operation without shutting down the system, tower basins and drift eliminators must be observed during monitoring and the presence of organic material, biofilm, algae, scale, sediment and silt/dust deposits, organics (oil and grease), and other visible contaminants observed must be noted on the checklist.
  - (4) The responsible person must observe and note the condition of chemical dosing and control equipment and the bleed-off system, and determine if there is sufficient storage and delivery of treatment chemicals.
  - (5) Any system anomalies or problems must be recorded on the checklist and reported to the management and maintenance team for immediate corrective action.

- (b) *Compliance inspections.* An owner must retain a qualified person to conduct a compliance inspection at least once every ninety (90) days while a cooling tower system is in operation. The qualified person must complete and the owner must maintain a written or electronic checklist containing observations and findings with respect to any of the following:
  - (1) Presence of organic material, biofilm, algae, and other visible contaminants.
  - (2) General condition of the tower, the basin, packing material and drift eliminator.
  - (3) Quality of water makeup connections and control.
  - (4) Proper functioning of the conductivity control.
  - (5) Proper functioning of all dosing equipment (pumps, strain gauges).
  - (6) Review of routine maintenance records to ensure proper implementation of required activities and corrective actions as needed.
- (c) *Maintenance.*
  - (1) *Routine maintenance.* Cooling tower systems must be maintained and operated in accordance with the maintenance program and plan. Routine maintenance must address all components and operations, including, but not limited to, general system cleanliness, drift eliminator and fill material condition, overall distribution operation, water treatment system, basin/remote sump cleaning, and purging of stagnant and low-flow zones.
  - (2) *Replacement in kind.* Any replacement part or equipment used in a cooling tower must comply with the manufacturer's design and performance specifications. As applicable, replacement materials must be corrosion resistant and effectively prevent the penetration of sunlight. Any alteration or replacement of a cooling tower system must comply with the New York City Construction Codes
- (d) *Cleaning.* The cooling tower system must be cleaned whenever routine monitoring indicates a need for cleaning, but no less than twice a year, in accordance with the maintenance program and plan. Cleaning protocol indicated by the manufacturer's instructions or industry standards, and worker protective measures, as required by applicable law must be specified in the maintenance program and plan. Water contact areas such as the basin, sump, fill, spray nozzles and fittings, drift eliminators and air intake louvres must be properly accessed or removed to facilitate cleaning.
- (e) *Aerosol and mist control.* The cooling tower system must be operated at all times to minimize the formation and release of aerosols and mist. Owners must install and maintain drift eliminators in accordance with the manufacturer's specifications and the New York City Construction Codes. The calculated drift loss at maximum design water circulation must not exceed the manufacturer's tested value for maximum drift loss. Counter-flow cooling towers must achieve a reduction of drift loss to no more than 0.002% percent of the recirculated water volume; cross-flow cooling towers must achieve a reduction of drift loss to no more than 0.005% of the recirculated water volume.

**§8-05 Water treatment.** Prior to changing an existing chemical treatment system or introducing a new chemical treatment agent, cooling tower design, installation, operation, and maintenance must be evaluated by a qualified person to ensure compatibility between the chemicals and the cooling tower system's materials, and to minimize microbial growth and the release of aerosols. The evaluation must describe the optimum level of chemicals to achieve the desired result in a manner which can be used as a system performance measure.

- (a) *Daily automatic treatment while in operation.* Water in a cooling tower system must be treated at least once a day when the system is in operation and such treatment must be automated, unless the maintenance program and plan explicitly states how manual or less frequent biocide additions will provide effective control of *Legionella* growth.
- (b) *Recirculating system.* A cooling tower system must be operated and programmed to continually recirculate the water irrespective of the building's cooling demand of the system, unless the maintenance program and plan specifies in detail how the intended water treatment schedule will be carried out, and how effective biofilm and microorganism control will be achieved when the whole or a part of the system is idle during the scheduled chemical injection.

- (c) *Chemicals and biocides.* Chemicals and biocides must be used in quantities and combinations sufficient to control the presence of *Legionella*, minimize biofilms, and prevent scaling and corrosion that may facilitate microbial growth. Only New York State Department of Environmental Conservation approved oxidizing chemicals may be used as the primary biocide control. For systems where oxidizing chemicals cannot be used as the primary biocide to control the presence of *Legionella* building owners must submit an alternative plan for effective bacteriological control for approval by the Department.
- (1) *Biocide applications.* Any person who performs cleaning and disinfection or applies biocides in a cooling tower system must be a commercial pesticide applicator or a pesticide technician certified in accordance with the requirements of Article 33 of the New York State Environmental Conservation Law and 6 NYCRR Part 325, or a pesticide apprentice under the supervision of a certified applicator.
  - (2) *Registered biocides.* Only biocide products registered with the New York State Department of Environmental Conservation may be used to meet the disinfection requirements of this Chapter.
  - (3) *Records.* Water treatment records must be kept for all chemicals and biocides added, noting the purpose of their use, the manufacturer's name, the brand name, the safety data sheet, the date and time of each addition, and the amount added each week.
  - (4) *Chemical and biocide additions.* Chemicals and biocides must be added in accordance with this section and the procedures described in the maintenance program and plan addressing, as applicable, feeding mechanism, feeding location, frequency, set timer, duration, triggering events, control procedures, and target biocide residuals. Water treatment chemicals and biocides must be used in accordance with the product label and manufacturer's instructions.
- (d) *Non-chemical water treatment devices restricted.* Only biocide products registered with the New York State Department of Environmental Conservation may be used to meet the disinfection requirements of this Chapter. Non-chemical water treatment devices that employ alternative technologies to control biological growth may not be used in lieu of chemical biocide unless approved by the Department. Non-chemical water treatment devices may be installed as part of a cooling tower system as specified in the management program and plan, provided that the required chemical water treatment also being used adequately controls for *Legionella*.
- (e) *Makeup water.* Owners using water derived from rainwater capture or recycling water systems as a source of cooling tower system makeup water must install a drift eliminator and test and treat water in accordance with a specific alternative source water plan. This plan is in addition to the maintenance program and plan required by §8-03 of this Chapter, and must be approved by the Department. The alternative water source plan must include provisions for adequate design of the treatment and control components and on-going evaluation to eliminate any risk to public health.
- (f) *Water quality monitoring.*
- (1) *Frequency.* Water quality parameters, including but not limited to pH, temperature, conductivity and biocidal indicators, must be measured and recorded as specified in the management program and plan as follows:
    - (A) *Manual measurements.* At least three times each week, provided that no more than two days pass without such measurement when the cooling tower system is operating.
    - (B) *Continuous, automated and/or remote measurements.* When continuous, automated and/or remote measurements and recordings are used, the management program and plan must show how effective measurements of system process control are being monitored. Automated measurements must be properly recorded and results made immediately available to responsible and qualified persons and to Department inspectors when requested.
  - (2) *Minimum weekly biological process control indicators.* A bacteriological indicator to estimate microbial content of recirculating water must be collected and interpreted in accordance with Table 8-2 at least once each week while the cooling tower system is operating. Indicators must be taken at times and from water sampling points, as detailed in the maintenance program and plan, that will be representative of water microbial content. Indicators may be taken at any time

from constant chemical treatment systems. Indicators from systems that use intermittent biocide applications must be taken before biocide application and reflect normal cooling tower operating conditions.

- (3) *Legionella samples.* *Legionella* culture testing must be conducted no less frequently than every 90 days during cooling tower system operation. A *Legionella* sample must be analyzed by a US Centers for Disease Control and Prevention ELITE Program certified laboratory, by the New York State Department of Health Wadsworth Center or other laboratory approved by the Department. Test results of all *Legionella* species at or above the magnitude of level 4 as indicated in Table 8-1 must be reported to the Department within 24 hours of receiving the test results. Additional emergency *Legionella* sampling must be conducted if any of the following occur:
- (A) Power failure of sufficient duration to allow for growth of bacteria;
  - (B) Loss of biocide treatment sufficient to allow for growth of bacteria;
  - (C) Failure of conductivity controls to maintain proper cycles of concentration;
  - (D) At the request of the Department upon a determination that one or more cases of legionellosis is or may be associated with the cooling tower, based on epidemiological data or laboratory testing,
  - (E) Any time two consecutive bacteriological indicator sample results are above Level 4 as indicated in Table 8-2; or
  - (F) Any other conditions specified by the Department.
- (4) *Monitoring and sampling locations.* System monitoring and sampling locations must be representative of the entire cooling tower system. The system must be operating with water circulating in the system for at least one hour prior to water quality measurements or collection of samples.
- (5) *Water quality corrective actions.* The maintenance program and plan must identify the procedures, responsible parties, required response time(s) and notification protocol for corrective actions and must include, at a minimum, corrective actions that must be implemented according to the result levels in Table 8-1 and Table 8-2.

**Table 8-1. Corrective actions required for *Legionella* culture results.**

<b>Level</b>	<b><i>Legionella</i> Culture Result<sup>1</sup></b>	<b>Process Triggered by <i>Legionella</i> Culture Results</b>
1	<10 CFU/ml	Maintain water chemistry and biocide levels.
2	≥ 10 CFU/ml to <100 CFU/ml	Initiate immediate disinfection by increasing biocide concentration or using a different biocide within 24 hours; review treatment program; and retest water within 3-7 days. Subsequent test results must be interpreted in accordance with this Table until level 1 is reached.
3	≥ 100 CFU/ml to <1000 CFU/ml	Initiate immediate disinfection by increasing biocide concentration or using a different biocide (within 24 hours), reviewing treatment program, performing visual inspection to evaluate need to perform cleaning and further disinfection. Retest water within 3-7 days. Subsequent test results must be interpreted in accordance with this Table until level 1 is reached.

4	≥ 1000 CFU/ml	Initiate immediate disinfection by increasing biocides within 24 hours. Within 48 hours perform full remediation of the tower by hyperhalogenating <sup>2</sup> , draining, cleaning, and flushing. Review treatment program, retest water within 3-7 days. Subsequent test results must be interpreted in accordance with this Table until level 1 is reached. For <i>Legionella</i> results at this level, notify Department within 24 hours of receiving test result. <sup>3</sup>
---	---------------	---

1. Performed by a CDC ELITE Laboratory, or NYSDOH Wadsworth Laboratory, or another laboratory approved by the Department. Combine all species of *Legionella* detected.
2. At a minimum, dose the cooling water system with 5 to 10 ppm Free Halogen Residual for at least 1 hour; pH 7.0 to 7.6.
3. In a manner as specified on the Department's website.

**Table 8-2. Corrective actions required for bacteriological indicator results.**

Level	Heterotrophic Plate Count <sup>1</sup> and Dip Slide Result	Process Triggered by Test Results
1	<10,000 CFU/ml	Maintain water chemistry and biocide levels.
2	≥ 10,000 CFU/ml to <100,000 CFU/ml	Initiate immediate disinfection by increasing biocide concentration or using a different biocide within 24 hours, review treatment program, retest water within 3-7 days. Subsequent test results must be interpreted in accordance with this Table until level 1 is reached.
3	≥ 100,000 CFU/ml to <1,000,000 CFU/ml	Initiate immediate disinfection by increasing biocide concentration or using a different biocide within 24 hours, reviewing treatment program, performing visual inspection to evaluate need to perform cleaning and further disinfection. Retest water within 3-7 days. Subsequent test results must be interpreted in accordance with this Table until level 1 is reached.
4	≥ 1,000,000 CFU/ml	Initiate immediate disinfection by increasing biocides within 24 hours. Within 48 hours perform remediation of the tower by hyperhalogenating <sup>2</sup> , cleaning, and flushing. Review treatment program, retest water within 3-7 days. Subsequent test results must be interpreted in accordance with this Table until level 1 is reached.

1. Performed by an appropriately accredited Laboratory (e.g. NELAP, AALA).
2. At a minimum, dose the cooling water system with 5 to 10 ppm Free Halogen Residual for at least 1 hour; pH 7.0 to 7.6.



**§8-06 System shutdown and start-up; commissioning and decommissioning cooling towers.**

- (a) *Full system shutdown.* Procedures to shut a cooling tower system must conform to the manufacturers' recommendations. When shut down, the system must be completely drained and protected from offline contamination.
- (b) *Full system startup.* At a minimum, before cooling tower system start-up, an owner must clean and disinfect a cooling tower that has been shut down or idle for more than five days, in accordance with §17-194.1 of the Administrative Code. Cleaning and disinfection must be done no later than 15 days before the first seasonal use of such tower. The maintenance program and plan must include detailed seasonal and idle period startup procedures that include, at a minimum:
  - (1) Either fully clean and disinfect, drain to waste and disinfect, or sufficiently hyperhalogenate the recirculated water before startup; and
  - (2) Before the startup of a cooling tower system after an extended shutdown of five or more days, collect samples for *Legionella* culture and take actions required by Table 8-1 when results are received; and
  - (3) Before seasonal startup of a system that has been fully shut down, perform a pre-startup inspection by a qualified person.
- (c) *Commissioning new cooling towers.* Newly installed cooling tower systems must be cleaned and disinfected prior to operation according to this section and the maintenance program and plan, and be registered with the Department of Buildings cooling tower registration system in accordance with § 28-317.3 of the Administrative Code.
- (d) *Removal or permanently discontinuing use of cooling towers.* The owner of a cooling tower must notify the Department of Buildings electronically within 30 days after removing or permanently discontinuing use of a cooling tower in accordance with § 28-317.3.1 of the Administrative Code. Such notice must include a statement that the cooling tower has been drained and sanitized in accordance with this section.

**§8-07 Records.**

- (a) *Records.* An owner must keep for at least three (3) years in the building where a cooling tower is located or in an adjacent building or structure on the same campus, complex, lot, mall or on-site central engineering division a record of any maintenance, inspection, deficiency, corrective action, water treatment, test result, cleaning or disinfection performed on the tower.
- (b) *Certification.* The owner of a cooling tower must file an annual certification each year as specified by the Department of Buildings, indicating that such tower was inspected, tested, cleaned and disinfected in accordance with the maintenance program and plan, as required by § 28-317.5 of the Administrative Code. The certification must document any deviations from compliance with the maintenance program and plan and the corrective actions taken to address any deficiencies.
- (c) *Posting.* The owner must post the Department of Buildings Cooling Tower Registration Number that has been assigned to that cooling tower on each cooling tower. The Registration Number must be posted on a sign or plate that is securely fastened to the cooling tower in a location that is conspicuously visible and must be constructed of a durable, weather resistant material.

**§8-08 Modification.** The Commissioner or designee may grant a modification when strict application of any provision of this Chapter presents practical difficulties or unusual hardships. The Commissioner in a specific instance may modify the application of such provision consistent with the general purpose of this Chapter and in compliance with Administrative Code §17-194.1 and upon such conditions as, in his or her opinion, are necessary to protect the health or safety of the public.

**§8-09 Penalties.** The following penalties shall be imposed for sustained initial and repeat violations. All penalties, except for those alleging a violation of the State Sanitary Code, must be doubled if the respondent fails to appear to answer such violation and is found in default.

<b>Section of Law</b>	<b>Description</b>	<b>Penalty: First violation</b>	<b>Repeat violation(s)</b>
24 RCNY §8-03	No maintenance program and plan	\$1000	\$2000
24 RCNY§8-03	Maintenance program and plan incomplete or not on premises	\$500	\$1000
24 RCNY §8-04(a)	Routine monitoring not conducted, documented at least once a week when tower is in use	\$500	\$1000
24 RCNY§8-04(b)	Compliance inspections not conducted, documented at least once every 90 days when the tower is in use	\$500	\$1000
24 RCNY §8-04(c)	Routine maintenance according to maintenance program and plan not conducted or documented	\$500	\$1000
24 RCNY§8-04(d)	Twice yearly or other required cleaning not conducted or documented	\$500	\$1000
24 RCNY §8-04(e)	Aerosol control do not meet manufacturer's design specifications or drift loss reduction requirements in new or existing towers when required	\$1000	\$2000
24 RCNY§8-05(a)	Daily automatic or approved alternative water treatment plan not provided	\$500	\$1000
24 RCNY§8-05(b)	Cooling water system not continually recirculated and no acceptable alternative	\$500	\$1000
24 RCNY §8-05(c)(1)	Use of an unqualified biocide applicator	\$500	\$1000
24 RCNY §8-05(c)(2)	Use of an unregistered biocide product	\$500	\$1000
24 RCNY §8-05(c)(3)	No records of all chemicals and biocides added	\$500	\$1000
24 RCNY §8-05(c)(4)	Sufficient quantities and combinations of chemicals not added as specified in the maintenance program and plan	\$500	\$1000

24 RCNY §8-05(d)	Using unacceptable alternative non-chemical water treatment device	\$500	\$1000
24 RCNY §8-05(e)	Use of captured rainwater or recycled water as makeup water not in accordance with approved alternative water source plan	\$1000	\$2000
24 RCNY §8-05(f)(1)	Minimum daily water quality measurements not taken or recorded	\$500	\$1000
24 RCNY §8-05(f)(2)	Failure to collect, analyze or record weekly biological process control indicators	\$500	\$1000
24 RCNY §8-05(f)(3)	<i>Legionella</i> samples not collected or analyzed, or results not recorded or reported to the Department as required	\$1000	\$2000
24 RCNY §8-05(f)(4)	Failure to monitor and sample from representative locations and times	\$500	\$1000
24 RCNY §8-05(f)(5)	Required corrective actions not taken based on bacteriological results	\$1000	\$2000
24 RCNY §8-06(a)	Improper or inadequate shutdown procedures	\$500	\$1000
24 RCNY §8-06(b)(1)	Improper or inadequate start-up procedures	\$500	\$1000
24 RCNY §8-06(b)(2)	<i>Legionella</i> samples not collected, analyzed before system start-up	\$500	\$1000
24 RCNY §8-06(c)	New cooling tower not or inadequately cleaned and disinfected prior to operating	\$500	\$1000
24 RCNY §8-07(a)	Failure to document all inspections, logs, tests, cleaning, and disinfection in accordance with the maintenance program and plan	\$500	\$1000
24 RCNY §8-07(a)	Failure to retain records for at least 3 years	\$500	\$1000

24 RCNY §8-07(a)	Required records not kept at the cooling tower premises	\$500	\$1000
24 RCNY §8-07(c)	Department of Buildings Cooling Tower Registration Number not posted as required	\$500	\$1000
24 RCNY §8-07(d)	Records not made immediately available to Department upon request	\$500	\$1000
State Sanitary Code Part 4	Miscellaneous provisions	\$250	\$250