



Heating Action Plan – Individual Action Plan

Jefferson Houses

DEVELOPMENT INFO	
# of Buildings	18
# of Apartments	1,493
Total Population	3,314
% of Population Over 62	20%
Self Identified Mobility Impaired Population	187
ASSET SUMMARY	
Plant Configuration	Dual Fuel
# of Boilers	5
Distribution System	Two-Pipe
ASSET CONDITION	
Boiler Age	11 years
Boiler PNA Condition Rating	2
MAJOR CHALLENGES	
This is a third-party location managed by George S. Hall (GSH). This site contains linkage-less burner systems, which require codes to make repairs. There are two vendors that can make repairs to the burner systems.	

CAPITAL INVESTMENTS	
<ul style="list-style-type: none"> Heating Controls [From November 2019 to Anticipated Completion of July 2020, 5% Completed] 	
OPERATIONS INVESTMENTS	
<ul style="list-style-type: none"> Boiler Repairs (By ACS) [Completed] Feedwater Valves and Pipe Replacement [Completed] Steam Valve Replacement [Completed] Sump Pump Replacements [Completed] 	
OUTAGES	
2017/2018 Heating Outages	15
2017/2018 Average Restoration Time (Hours)	15.8
2018/2019 Heating Outages	17
2018/2019 Average Restoration Time (Hours)	9.2
HEATING STAFF BREAKDOWN	
Cluster	-
Management	Heating administrator Cluster Superintendent
Frontline Personnel	Third Party Management/Property Management
Permanent Affordability Commitment Together (PACT)	
Jefferson is not currently in the PACT conversion pipeline	

POTENTIAL ALTERNATIVE HEATED COMMUNITY SPACES	
On-site	
Union Settlement Association, 2205 First Avenue	
Off-site	
Not Applicable	

The Office of Emergency Management (OEM) and the Emergency Services Department (ESD) coordinate with the MTA to provide warming buses and transportation to the warming centers.



Heating Action Plan – Individual Action Plan

Jefferson Houses

Manhattan

MOBILE BOILER CONNECTION DETAILS

Location of installation (DOT alternate side parking rules)	310 East 115th Street (NYCHA employee lot)
Boiler type	Johnston
Boiler burner	S.T. Johnson
Number of boilers	5
Internal heating system	Steam
Horsepower per boiler	400 hp
Internal system horsepower	2,000 hp
Number of in-ground oil tanks	2
In-ground oil tank capacity	25,000
Number of oil transfer pumps on-site	2
Number of oil transfer pumps operational	0
Oil operation follow-ups	Pump#1,2 - OOO
Scaffolding size and staging	Connection Platform: 25'H x 5'W; Bridging: 30'H x 3'W x 10'L
Electrical feed location	Boiler room main panel (spare breaker)
Building amperage/voltage	100 amp/ 208 volt
Electrical materials needed	3 Phase 50' length - 4/0 AWG cable
Steam inlet access point	Main header contains a spare king valve
Steam connection inlet diameter	10"
Requires welding for steam connection	No
Plumbing materials needed for steam connection	(1) 12" x 10" Reducer, (1) 90-degree elbow, (1) 20'L x 10" ID Steel Braided Hose, (1) 10'L x 10" ID Steel Braided Hose
Make-up feed water access point	Condensate header line
Plumbing materials needed for make-up feedwater connection	Reduced pressure zone (RPZ), 50'L x 2" Rubber Hose



LEGEND

- | | | | |
|---|---------------------|---|------------------------------------|
|  | NYCHA Buildings |  | Mobile Boiler Location |
|  | Development Outline |  | Alternative Heated Community Space |
|  | Boiler Room |  | Underground Steam Lines |