

NEW YORK STATE DEPARTMENT OF ENVIRONMENTAL CONSERVATION

Division of Water, Bureau of Water Compliance
625 Broadway, Albany, New York 12233-3506
P: (518) 402-8177 | F: (518) 402-8082
www.dec.ny.gov

June 10, 2015

SENT VIA EMAIL

Mr. Keith Beckmann, P.E.
Program Manager - LTCP
Bureau of Wastewater Treatment
New York City Department of Environmental Protection
96-05 Horace Holding Expressway
Corona, NY 11368

Re: Order on Consent ("CSO Order"), DEC Case #CO2-20110512-25 modification to DEC Case #CO2-20000107-8, Appendix A
XI.G. Submit Approvable Drainage Basin Specific LTCP for Hutchinson River

Dear Mr. Beckmann:

The New York State Department of Environmental Conservation (Department) acknowledges receipt of the Supplemental Documentation for the Hutchinson River Long-Term Control Plan (LTCP) received from the New York City Department of Environmental Protection (City) on April 14, 2015. The Department reviewed the Supplemental Documentation and provides the following additional comments:

1. DEP did not commit to a particular floatables control technology for HP-024 and did not commit to any floatables control for HP-023. With respect to HP-024, the Department needs additional assurance that floatables control for the outfall is feasible and requests that a preliminary engineering report or predesign site investigation report be submitted within 18 months of approval of the LTCP. The report shall confirm that the floatables control is feasible and provide specific information on the possible sites and technology to be used. With respect to HP-023, the Department requests that DEP conduct further field studies to confirm the quantity of floatables discharged from this outfall and include that information in the preliminary engineering report for HP-024.

Please respond to these comments within 60 days of the date of this letter. If the City would like to discuss the comments contained herein prior to submitting its formal response, the City must contact the Department to do so in a timely manner to ensure the 60 day deadline will be met. If you have any questions regarding this letter, please contact Mr. Gary E. Kline, P.E., Section Chief at 518-402-9655 or gekline@gw.dec.state.ny.us.



Department of
Environmental
Conservation

Sincerely,



Joseph DiMura, P.E.
Director, Bureau of Water Compliance
Division of Water

cc: All sent via email
G. Kline, P.E.
M. vonWergers, Esq.
L. Allen, P.E.
P. Kenline
R. Elburn, P.E.
S. Southwell, P.E.
K. Penner, P.E.
K. Anderson
S. Stephansen
W. Plache, Esq.
H. Donnelly, Esq.
J. Petito, P.E.
J. Mueller, P.E.
K. Mahoney, P.E.
L. Lee, P.E.
V. Sapienza, P.E.